

Project Reviews

City of Waukesha

Project Number: CU21-00007

Description: **Redemption Fitness**

Applied: **8/30/2021**

Approved:

Site Address: **2125 S WEST AV**

Closed:

Expired:

City, State Zip Code: **WAUKESHA, WI 53189**

Status: **UNDER REVIEW**

Applicant: **Maggie Ludwig**

Parent Project:

Owner: **J FITZGERALD REALTY LLC**

Contractor: **<NONE>**

Details:

PC21-0098

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: ALL						
9/13/2021	9/15/2021	9/14/2021	Sanitary Sewer	Chris Langemak		See comments
Notes:						
1. Sewer lateral video. The existing building has a sanitary sewer lateral connecting the City's sewer main. Please provide a sewer lateral video to City for review and approval. Contact the City Engineering Department for the video format. If lateral maintenance is needed, then the lateral improvements may need to be included as part of this project. The lateral pipe and connection to the main may need to be lined or relayed to reduce infiltration into the City's sanitary sewer system or improve the structural integrity.						
Review Group: AUTO						
8/30/2021		9/22/2021	BUILDING INSPECTION	KRISTIN STONE		
Notes:						
8/30/2021		9/12/2021	Fire	Brian Charlesworth		
Notes:						
8/30/2021	9/13/2021	9/12/2021	General Engineering	DAVID BUECHL	REVIEW COMPLETE	see notes
Notes:						
1. No comments.						
8/30/2021		9/12/2021	Planning	Unassigned		
Notes:						
8/30/2021		9/12/2021	Planning Commission	Unassigned		
Notes:						