

Project Reviews

City of Waukesha

Project Number: CU20-00020

Description: **Fresh Paws of MKE LLC**

Applied: **12/28/2020**

Approved:

Site Address: **143 WILSON AV**

Closed:

Expired:

City, State Zip Code: **WAUKESHA, WI 53186**

Status: **UNDER REVIEW**

Applicant: **Phillip Ludwig, Fresh Paws of MKE LLC**

Parent Project:

Owner: **AMI K SHOCKLEY**

Contractor: **<NONE>**

Details:

PC20-0135 and PC20-0136

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: ALL						
1/4/2021	1/12/2021	1/11/2021	Sanitary Sewer	Chris Langemak		See comments
Notes:						
1. Sewer lateral video. The existing building has a sanitary sewer lateral connecting the City's sewer main. Please provide a sewer lateral video to City for review and approval. Contact the City Engineering Department for the video format. If lateral maintenance is needed, then the lateral improvements may need to be included as part of this project. The lateral pipe and connection to the main may need to be lined or relayed to reduce infiltration into the City's sanitary sewer system or improve the structural integrity.						
1/4/2021	1/5/2021	1/11/2021	Street Lighting	JEFF HERNKE	REVIEW COMPLETE	See notes
Notes:						
No comments regarding City owned street lights or fiber.						
1/4/2021	1/13/2021	1/11/2021	Traffic	Michael Grulke	REVIEW COMPLETE	No Comments
Notes:						
1/4/2021		1/11/2021	Wastewater Quality	TIM YOUNG		
Notes:						
Review Group: AUTO						
12/28/2020		1/11/2021	Building Inspection	KRISTIN STONE		
Notes:						
12/28/2020		1/11/2021	Fire	Brian Charlesworth		
Notes:						

Project Reviews

City of Waukesha

12/28/2020	1/11/2021	1/11/2021	General Engineering	DAVID BUECHL	REVIEW COMPLETE	see notes
Notes:						
1. No comments.						
12/28/2020		1/11/2021	Water Utility	Chris Walters		
Notes:						
1/7/2021		1/17/2021	Planning	ROBIN GRAMS		
Notes:						