



FIRE DEPARTMENT
FIRE PREVENTION BUREAU
130 W. ST. PAUL AVENUE
WAUKESHA, WISCONSIN 53188-5172
TELEPHONE: (262) 524-3648 FAX: (262) 524-3670

Brian Charlesworth, Fire Marshal
bcharles@ci.waukesha.wi.us

**CITY OF WAUKESHA FIRE DEPARTMENT
PROPOSED PROJECTS FOR PLAN COMMISSION
MEETING OF FEBRUARY 24, 2016**

- 1) CALL TO ORDER
- 2) PLEDGE OF ALLEGIANCE
- 3) ROLL CALL
- 4) APPROVAL OF MINUTES
 - A. (ID#16-133) MINUTES FOR THE FEBRUARY 10, 2016 MEETING
 - No Concerns/Issues Noted
- 5) CONSENT AGENDA
 - A. (PC15-0256) MAINSTREAM BAR & GRILLE – 400-402 W. MAIN STREET – CERTIFIED SURVEY MAP
 - No Concerns/Issues Noted
 - B. (ID#16-208) 1920 MADERA STREET – REQUEST FOR HAZARDOUS IDENTIFICATION FROM THE STATE OF WISCONSIN FOR A PROPOSED COMMUNITY LIVING ARRANGEMENT
 - The City of Waukesha Fire Department did not identify any hazards in the immediate area of 1920 Madera Street. There is a railroad line that does carry hazardous materials, but it is located approximately 1,400 ft. from this property.
- 6) BUSINESS ITEMS
 - A. (PC16-0001) STILLWATER VILLAS – PRELIMINARY SITE PLAN & ARCHITECTURAL REVIEW
 - The water utility plan and the landscaping plan appear to have a conflict where the hydrant is proposed to be located. It will be necessary to work with the Waukesha Water Utility to adjust these plans so there is no conflict between the fire hydrant and tree locations.