



FIRE DEPARTMENT
FIRE PREVENTION BUREAU
130 W. ST. PAUL AVENUE
WAUKESHA, WISCONSIN 53188-5172
TELEPHONE: (262) 524-3648 FAX: (262) 524-3670

Brian Charlesworth, Fire Marshal
bcharles@ci.waukesha.wi.us

**CITY OF WAUKESHA FIRE DEPARTMENT
PROPOSED PROJECTS FOR PLAN COMMISSION
MEETING OF AUGUST 10, 2016**

- 1) CALL TO ORDER
- 2) PLEDGE OF ALLEGIANCE
- 3) ROLL CALL
- 4) APPROVAL OF MINUTES
 - A. (ID#16-1189) MINUTES FOR THE JULY 27, 2016 MEETING
 - No Concerns/Issues Noted
- 5) CONSENT AGENDA
- 6) BUSINESS ITEMS
 - A. (PC15-0251) WAUKESHA COUNTY MUSEUM - 101 W. MAIN ST. – PRELIMINARY SITE PLAN & ARCHITECTURAL REVIEW
 - Per City of Waukesha Municipal Ordinance 21.07 and the State of Wisconsin building codes, this entire project will need to be protected by an automatic fire sprinkler system. This building will also be required to have an automatic fire alarm system in accordance with International Fire Code Chapter 9. This project will also need to comply with International Fire Code Section 510 for emergency responder radio coverage.
 - B. (PC16-0061) COAST CAR WASH – 905 ANITOL AVE. - REZONING
 - No Concerns/Issues Noted
 - C. (PC16-0062) COAST CAR WASH – 905 ANITOL AVE. – PRELIMINARY CONDITIONAL USE PERMIT
 - No Concerns/Issues Noted
 - D. (PC16-0063) POPLAR CREEK – 20118 BLUEMOUND RD. (BROOKFIELD) – EXTRA TERRITORIAL CERTIFIED SURVEY MAP
 - No Concerns/Issues Noted
 - E. (PC16-0064) POPLAR CREEK – 20120 BLUEMOUND RD. (BROOKFIELD) – EXTRA TERRITORIAL CERTIFIED SURVEY MAP
 - No Concerns/Issues Noted
 - F. (PC16-0065) 1104-1108 MADISON STREET – CERTIFIED SURVEY MAP
 - No Concerns/Issues Noted