

Project Reviews

City of Waukesha

Project Number: SPAR25-00073

Description: **2310 Fox Run Blvd**

Applied: **1/5/2026**

Approved:

Site Address: **2310 FOX RUN BLVD**

Closed:

Expired:

City, State Zip Code: **WAUKESHA, WI 53188**

Status: **RECEIVED**

Applicant: **Brian Griebel / VJS Construction Services**

Parent Project:

Owner: **Fox Run 3 LLC**

Contractor: **<NONE>**

Details:

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: AUTO						
1/5/2026	1/6/2026	1/19/2026	Building Inspection	KRISTIN STONE	REVIEW COMPLETE	
Notes: After approval, plans will be required to be sent to E plan Exam for review and approval prior to submittal for any building permit.						
1/5/2026	1/6/2026	1/19/2026	Fire	Brian Charlesworth	REVIEW COMPLETE	see notes
Notes: This building will be required to be protected by an automatic fire sprinkler system.						
1/5/2026		1/19/2026	General Engineering	Josh Meyerhofer		
Notes:						
1/5/2026		1/19/2026	Parks	Melissa Lipska		
Notes:						
1/5/2026	1/20/2026	1/19/2026	Planning	Doug Koehler	REVIEW COMPLETE	See notes.
Notes: 1. Provide catalog cuts for exterior lighting fixtures and poles. 2. Provide details for short term and long term bicycle parking facilities. 3. Identify storage space for tenant units.						
1/5/2026		1/19/2026	Planning Commission	Unassigned		
Notes:						

Project Reviews

City of Waukesha

1/5/2026	1/6/2026	1/19/2026	Water Utility	Mat Kadrich	REVIEW COMPLETE	No comments
Notes:						