

CJ Engineering, LLC
9205 W. Center Street, Suite 214
Milwaukee, WI 53222
Phone (414) 443-1312
randy@cj-engineering.com

Revision Memorandum

To: Dave Buechl

CC:

From: Randall S. Bruckner, P.E.

Date: 2/15/2019

Re: Revisions to Brelie Gear, City of Waukesha, WI. The following revisions are based on specified comments on the Civil Plans dated January 22, 2019

Comments:

- #1a: Storm Water Erosion Control Permit forwarded to Applicant for completion and submittal
- #1b: NOI is attached.
- #2a: Exhibit for expansion of existing storm sewer easement attached.
- #4: Each Civil sheet stamped/signed.
- #6: See note #12 on sheet C3.0.

Stormwater

- #2: Exhibit for expansion of existing storm sewer easement attached.
- #2b: Ditch storm sewer extended to east with new public inlet and public manhole.
- #8: Plans show proposed contours along future sidewalk location as well as a note indicating contractor to grade ROW within project disturbance limits.

If you should have any additional questions or comments, please feel free to contact me directly.

Sincerely,

Randy Bruckner, P.E.