


- LEGEND**
- ① POTENTIAL DEVICE
 - ② LOAD BREAK SWITCH WITH AUTOMATIC OPERATOR
 - ③ 34.5KV, 600A. DISCONNECT SWITCH
 - ④ TRANSFORMER, 8400/10500 KVA, 26.4/18.73 KV
 - ⑤ 27KV, 800A. VACUUM RECLOSER

REF. DWG. (60 ADDN)
 TDS 4639-L - FUSE STRUCT FDN
 TDS 4638-D - DISC. SW. FDN.
 TDS 4618-E - SWGR FDN
 TD 6782-D - TRANSF. FDN.
 TDS 5431-F - STORAGE SHED FDN.

NE 1/4 OF THE NE 1/4 SECTION 16
 T-6-N R-16-E TOWN OF WAUKESHA
 WAUKESHA COUNTY



REFERENCE DRAWINGS										LEVEL USAGE		CGS REF FILES		MICROFILM NO.		WISCONSIN ELECTRIC CGS NO. 71759C		PROPERTY PLAN & ELEVATION 26.4 KV - 8.3/4.8 KV WEWAUK SUBSTATION	
										1 2 3 4 5 6 7 8 9				182374					
										10 11 12 13 14 15 16 17 18				DRAWN DATE PROJECT NO.					
										19 20 21 22 23 24 25 26 27				CHECKED DATE ACTIVITY NO.					
										28 29 30 31 32 33 34 35 36				APPROVED DATE SCALE		1"=20'		DWEW121PANL00000113	
										37 38 39 40 41 42 43 44 45									
										46 47 48 49 50 51 52 53 54									
										55 56 57 58 59 60 61 62 63									
REV NO.	DATE	REVISION DESCRIPTION			ACT	DRAWN	CHK'D	APPR'D	REV NO.	DATE	REVISION DESCRIPTION			ACT	DRAWN	CHK'D	APPR'D		

© WISCONSIN ELECTRIC 1996

WAS: TD-5437-F-52