

**Resolution #9-20-18 of the WAUKESHA WATER UTILITY**

**Arcadian Water Main Railroad Crossing Repair**

**September 20, 2018**

WHEREAS, a water main break in the 8-inch line under the railroad crossing on Arcadian has been experienced; and

WHEREAS, the customer's health and safety in the area could be in jeopardy due to the incomplete looping of water main and the potential of damage to the railroad facilities in the area; and

WHEREAS, the situation calls for replacement/repair of the 8-inch water main line contained within the 18-inch casing under the railroad crossing on Arcadian between Hartwell and Caroline as soon as possible to ensure the ability of the Utility to provide adequate water for drinking and fire protection in the area, and to avoid potential damage to the railroad facilities; and

THEREFORE BE IT RESOLVED, that the Waukesha Water Utility Commission hereby declares that an emergency situation exists, as described in Section 62.15 (1)(b) of the Wisconsin Statutes, and directs the General Manager to secure a qualified contractor to make necessary repairs to the 8-inch water main line contained within the 18-inch casing under the railroad crossing on Arcadian between Hartwell and Caroline for a cost not to exceed \$150,000.

Adopted on \_\_\_\_\_.

**WAUKESHA WATER UTILITY COMMISSION**

\_\_\_\_\_  
Joseph J. Piatt, President

\_\_\_\_\_  
G. J. Zinda, Secretary