

Project Reviews

City of Waukesha

Project Number: SPAR26-00010

Description: **620 Northview Rd, Northview Hangers**

Applied: **2/23/2026**

Approved:

Site Address: **620 NORTHVIEW RD**

Closed:

Expired:

City, State Zip Code: **WAUKESHA, WI 53188**

Status: **RECEIVED**

Applicant: **Dedicated Construction Management / Keith Tubin**

Parent Project:

Owner: **<NONE>**

Contractor: **<NONE>**

Details:

PC26-0017

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: AUTO						
2/23/2026	2/23/2026	3/9/2026	Building Inspection	KRISTIN STONE	REVIEW COMPLETE	no remarks
Notes:						
2/23/2026	2/25/2026	3/9/2026	Fire	Brian Charlesworth	REVIEW COMPLETE	See Notes
Notes:						
Fire Protection will need to be evaluated under the IBC and NFPA 409						
2/23/2026	3/11/2026	3/9/2026	General Engineering	Josh Meyerhofer	REVIEW COMPLETE	See notes
Notes:						
MSA comments in attachments.						
2/23/2026		3/9/2026	Parks	Melissa Lipska		
Notes:						
2/23/2026		3/9/2026	Planning	Doug Koehler		
Notes:						
2/23/2026		3/9/2026	Planning Commission	Unassigned		
Notes:						

Project Reviews

City of Waukesha

2/23/2026	2/23/2026	3/9/2026	Water Utility	Mat Kadrich	REVIEW COMPLETE	see notes
-----------	-----------	----------	---------------	-------------	-----------------	-----------

Notes:

- 1) WWU will need a water lateral application for each service that will be installed for meter sizing. Application can be found on our website with associated fees.
- 2) WWU will supply the tapping saddle, corporation, and curb box. WWU will also make the tap.
- 3) Contractor is responsible for excavation, and shoring.