

Project Reviews

City of Waukesha

Project Number: CU21-00011

Description: **Use basement as an at home salon**

Applied: **9/27/2021**

Approved:

Site Address: **347 DELAFIELD ST**

Closed:

Expired:

City, State Zip Code: **WAUKESHA, WI 53188**

Status: **UNDER REVIEW**

Applicant: **Rachel Lundman**

Parent Project:

Owner: **STEPHANIE J SCHERZBERG**

Contractor: **<NONE>**

Details:

PC21-0112

LIST OF REVIEWS

| SENT DATE | RETURNED DATE | DUE DATE | TYPE | CONTACT | STATUS | REMARKS |
|---|---------------|------------|---------------------|--------------------|-----------------|--------------|
| Review Group: ALL | | | | | | |
| 10/11/2021 | 10/13/2021 | 10/12/2021 | Sanitary Sewer | Chris Langemak | | See comments |
| Notes: | | | | | | |
| 1. Sewer lateral video. The existing building has a sanitary sewer lateral connecting the City's sewer main. Please provide a sewer lateral video to City for review and approval. Contact the City Engineering Department for the video format. If lateral maintenance is needed, then the lateral improvements may need to be included as part of this project. The lateral pipe and connection to the main may need to be lined or relayed to reduce infiltration into the City's sanitary sewer system or improve the structural integrity. | | | | | | |
| Review Group: AUTO | | | | | | |
| 9/27/2021 | | 10/15/2021 | BUILDING INSPECTION | KRISTIN STONE | | |
| Notes: | | | | | | |
| 9/27/2021 | | 10/11/2021 | Fire | Brian Charlesworth | | |
| Notes: | | | | | | |
| 9/27/2021 | 10/11/2021 | 10/11/2021 | General Engineering | DAVID BUECHL | REVIEW COMPLETE | see notes |
| Notes: | | | | | | |
| 1. No comments. | | | | | | |
| 9/27/2021 | 10/22/2021 | 10/11/2021 | Planning | Unassigned | REVIEW COMPLETE | |
| Notes: | | | | | | |
| 9/27/2021 | | 10/11/2021 | Planning Commission | Unassigned | | |
| Notes: | | | | | | |

Project Reviews

City of Waukesha

| | | | | | | |
|-----------|------------|------------|---------------|---------------|----------|-------------|
| 9/27/2021 | 10/19/2021 | 10/11/2021 | Water Utility | Chris Walters | APPROVED | No comments |
| Notes: | | | | | | |