



# Waukesha Water Utility

SERVING WAUKESHA SINCE 1886

115 DELAFIELD STREET  
WAUKESHA, WI 53188-3615

Telephone: (262) 521-5272 • Fax: (262) 521-5265 • E-mail: [contactus@waukesha-water.com](mailto:contactus@waukesha-water.com)

## MEMORANDUM

DATE: January 14, 2016

TO: Dan Duchniak

FROM: Jeff Detro

RE: Approve Pressure Reducing Valves for Highline Booster

I respectfully request approval to purchase two 8"x2" pressure reducing valves (PRV) manufactured by Cla-Val from HD Supply for their low proposal.

This equipment will be used to transfer water from the Southeast high level zone to the Southeast reduced pressure zone.

This equipment will be located inside the Highline Booster Station. One of the PRV's will be replacing a 15 year old valve currently located in an underground vault and the second PRV will supply water to a new 12" water main being installed as part of the Les Paul water main project phase 2.

A fund for this budgeted equipment is available in capital account 3431.

| BIDDER   | COST               |
|--|--------------------|
| Dorner Company<br>N61 W23043 Silver Spring Drive<br>Sussex, Wisconsin, 53089                             | \$25,300.00        |
| <b>HD Supply Waterworks, LTD</b><br><b>15655 West Rogers Drive</b><br><b>New Berlin, Wisconsin 53151</b> | <b>\$24,990.00</b> |

**Recommended Motion:** Move to approve the purchase of two Cla-Val Model 90-99KX pressure reducing valves for the cost of \$24,990.00 from HD Supply.