

Project Reviews

City of Waukesha

Project Number: SPAR17-00005

Description: **Automatic Entrances of WI**

Applied: **2/13/2017**

Approved:

Site Address: **1712 PARAMOUNT CT**

Closed:

Expired:

City, State Zip Code: **WAUKESHA, WI 53186**

Status: **UNDER REVIEW**

Applicant: **Payne and Dolan, Inc.**

Parent Project:

Owner: **WMH/JJW INVESTMENTS LLP**

Contractor: **<NONE>**

Details:

PC17-0018

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: AUTO						
2/13/2017	3/13/2017	2/13/2017	Building Inspection	Michael Mazmanian	REVIEW COMPLETE	see conditions of approval
Notes: Drawings do not indicate curb ramps to provide fully accessible route from new handicapped spaces. Provide fully accessible path in accordance with ANSI A117.1-2003. Maintain required landing space and turning radii.						
2/13/2017	3/20/2017	2/13/2017	Fire	Brian Charlesworth	REVIEW COMPLETE	None
Notes:						
2/13/2017	3/7/2017	2/13/2017	General Engineering	DAVID BUECHL	REVIEW COMPLETE	See notes
Notes: 1. The following items should be submitted: a. Applicable fees per Chapter 32.07(b). The Engineering Division requires any Bonds or Agreements required by the Plan Commission and Council or Chapter 32.08(c). Development fees will be owed to the City for this project. b. Chapter 32.07(b)(2): Once all submittal items are completed, submit all items listed in sub.(b)(1)(A)-(G) in digital form for City filing. 2. Confirm parking lot and walks designed in accordance with ADA requirements. 3. A City storm water permit will be needed.						
2/13/2017	3/17/2017	2/13/2017	Planning	Maria Pandazi	UNDER REVIEW	
Notes:						
2/13/2017	3/17/2017	2/13/2017	Planning Commission	Maria Pandazi	UNDER REVIEW	
Notes:						

Project Reviews

City of Waukesha

2/13/2017	3/8/2017	2/13/2017	Water Utility	Chris Walters	REVIEW COMPLETE	No comments.
-----------	----------	-----------	---------------	---------------	-----------------	--------------

Notes:
No Comments