## Project Reviews City of Waukesha

Project Number: SPAR22-00053 Description: Final Site Plan Review - 515 W. Moreland Blvd

Applied: 10/25/2022 Approved: Site Address: 515 W MORELAND BL

Closed: Expired: City, State Zip Code: WAUKESHA, WI 53188

Status: RECEIVED Applicant: Kueny Architects, LLC / Jon Wallenkamp

Parent Project: Owner: WAUKESHA COUNTY, C/O Shane Waeghe

Contractor: < NONE>

Details:

## PC22-0331

LIST OF REVIEWS								
SENT DATE	RETURNED DATE	DUE DATE	ТҮРЕ	CONTACT	STATUS	REMARKS		
Review Group: ALL								
10/27/2022		11/4/2022	Erosion Control	Cali Bonie				
Notes:								
10/27/2022	11/2/2022	11/4/2022	Sanitary Sewer	Chris Langemak	REVIEW COMPLETE	See comments		

## Notes:

1. A record drawing of the sanitary/storm sewer facilities sealed by a professional engineer or registered land surveyor shall be submitted to the Engineering Division.

At a minimum the drawing should include:

- Rim/cover elevation
- Invert elevation
- Distances
- Slopes
- Materials
- Contractor
- Installation dates (mouth and year completed)
- Any notes related to major field changes (ie additional/deleted structures, etc)
- Signed and sealed by professional engineer or registered land surveyor
- Autocad drawing for importing into GIS

A redlined copy of the plans with the proposed information crossed out and the actual information next to it is acceptable and helps the review process.

Review Group: AUTO

10/25/2022	11/14/2022	Building Inspection	KRISTIN STONE	

Notes:



## **Project Reviews City of Waukesha**

10/25/2022		11/4/2022	Fire	Brian Charlesworth			
Notes:		, ,,					
Notes.							
10/25/2022	11/8/2022	11/4/2022	General Engineering	DAVID BUECHL	ADDITIONAL INFO REQUIRED	see notes	
Notes:							
1. Pay impact fees for building addition area of 32,000 sf.; Police \$12,800 + sanitary sewer \$41,449.86 = \$54,249.86							
10/25/2022		11/4/2022	Parks	Melissa Lipska			
Notes:							
10/25/2022		11/4/2022	Planning	Unassigned			
Notes:							
10/25/2022		11/4/2022	Planning Commission	Unassigned			
Notes:							
10/25/2022		11/4/2022	Water Utility	Chris Walters			
Notes:							

