

Structural Calculations

For

Vertical LP Dispenser Tanks Wisconsin Installations

Prepared for
**Manchester Tank
Bedford, Indiana**

PACE Project Number 16857

October 25, 2017

Limitations

Engineer was retained in limited capacity for this project. Design is based upon information provided by the client, who is solely responsible for the accuracy of same. No responsibility and/or liability is assumed by, or is to be assigned to the engineer for items beyond that shown on these sheets. 38 sheets total including this cover sheet.



This Packet of Calculations is Null and Void if Signature above is not Original

PACE ENGINEERS, Inc.
5000 Meadows Road, Suite 345
Lake Oswego, OR 97035
(503) 597-3222 Fax (503) 597-7655



**Foundation and Anchorage Design
For Vertical LP Dispenser Tanks
PACE Job No. 16857**

**Structural Calculations
Table of Contents**

<u>Item</u>	<u>Sheets</u>
1. Master Data Sheet	MD1 – MD2
2. Load Analysis	1 – 3
3. Anchorage Design	4 – 20
4. Soil Bearing and Stability	21 – 23
5. Foundation Design	24 – 27
6. Tank Information	28 – 32
7. Foundation Sketch	33 – 34



MASTER DATA SHEET & DESCRIPTION

MD1

Project Description:

PACE Job No. 16857

The scope of this project includes evaluating the foundation and anchorage details for 1150 gallon, 1250 gallon, and 1600 gallon Vertical LP Dispenser Tanks installed on crash post assemblies. Analyses of the tanks, base frame, crash post assembly and related connections is outside PACE Engineer's scope of work and shall be performed by a qualified engineer. At the present time, dispenser tanks are anticipated to be installed at one location within the state of Wisconsin as listed below. The structural calculations incorporate higher wind speeds and seismic accelerations to accommodate future installations; however, tanks installed in Seismic Design Category C, D, E, or F regions will require structural calculations for the specific site.

Every installation of a Vertical LP Dispenser Tank needs to be reviewed by a qualified engineer to insure the tank and its foundation do not impact or apply loads to adjacent structures. Additionally, these calculations need to be reviewed each time the authority having jurisdiction approves changes to the local building code, including adopting a newer edition of the local building code.

Location of current installation:

- 835 E Green Bay Ave
Saukville, WI 53080



MASTER DATA SHEET & DESCRIPTION

MD2

Project Specifications:

Code: Wisconsin Administrative Code and Register, Chapter SPS 362
 "Buildings and Structures", Based on the 2012 International Building Code
 ASCE 7-10 Minimum Design Loads for Buildings and Other Structures
 NFPA 58 – 2017

Risk Category: III

Wind Design:

Basic Wind Speed	V_{ult}	200 MPH*	ASCE 7-10
Wind Exposure	Category:	D*	
Wind Analysis Procedure	Other Structures		ASCE 7-10

*This value represents a conservative value used for design. For local values, see sheet 3.

Seismic Design:

Spectral Response Coefficient –	S_{DS} :	0.33g**	USGS Hazard Maps
Spectral Response Coefficient –	S_{D1} :	0.133g**	USGS Hazard Maps
Seismic Design Category		B	ASCE 7-10
Importance Factors –	I_p :	1.5	ASCE 7-10
Response Modification Factor –	R_p :	2.0	ASCE 7-10

**This value represents a conservative value used for design. For local values, see sheet 2.

Material Data:

Steel:	All-thread rods	ASTM F1554 GR. 36
Concrete:	Foundations	$f'_c = 3000$ psi
Reinforcing:	Foundations	ASTM A615
Soils:	Bearing Pressure	750 psf – SPS 362.1806

Structural Analysis Software Used:

Hilti Profis Anchor



An Engineering Services Company

www.paceengrs.com

JOB NO. 16857
 JOB NAME VERTICAL LP DISPENSER
 SHEET NO. 1 OF _____
 CALCULATED BY CA DATE 10/13/16
 CHECKED BY _____ DATE _____

DEAD LOADS:

1150 GAL TANK: SELF-WEIGHT: 2920 #
 CONTENTS: (4.25#/GAL)(1150 GAL) = 4890 #
 CRASH POST: (ASSUMED) 390 #
 $\Sigma = 8200 \#$

1250 GAL TANK: SELF-WEIGHT: 3210 #
 CONTENTS: (4.25#/GAL)(1250 GAL) = 5310 #
 CRASH POST: 380 #
 $\Sigma = 8900 \#$

1600 GAL TANK: SELF-WEIGHT: 4040 #
 CONTENTS: (4.25#/GAL)(1600 GAL) = 6800 #
 CRASH POST: 360 #
 $\Sigma = 11,200 \#$

SEISMIC LOADS:

$V = C_s W$, $C_s = \frac{S_{DS}}{R/I}$, MAX $S_{DS} = .081$ IN SAUKVILLE
 USE $S_{DS} = .33 \Rightarrow$ SDC B
 $\Rightarrow \Omega$ DOES NOT APPLY

$R = 2.0$ ELEVATED TANK ON UNBRACED LEGS.
 $C_s = \frac{.33}{2.0/1.5} = .25 > \text{MIN } C_s = .044 S_{DS} I$
 $= .044(.33)(1.5)$
 $= .02 \checkmark$

$V = .25(8200 \#)$	$= 2050 \#$	(1150 GAL)
$.25(8900 \#)$	$= 2230 \#$	(1200 GAL)
$.25(11,200 \#)$	$= 2800 \#$	(1600 GAL)

USGS Design Maps Summary Report

SHEET: 2

User-Specified Input


Report Title 835 E Green Bay Ave
Wed October 25, 2017 16:37:29 UTC

Building Code Reference Document ASCE 7-10 Standard
(which utilizes USGS hazard data available in 2008)

Site Coordinates 43.38466°N, 87.92241°W

Site Soil Classification Site Class D - "Stiff Soil"



Risk Category I/II/III



USGS-Provided Output

$S_s = 0.076 \text{ g}$	$S_{MS} = 0.122 \text{ g}$	$S_{DS} = 0.081 \text{ g}$
$S_1 = 0.043 \text{ g}$	$S_{M1} = 0.103 \text{ g}$	$S_{D1} = 0.068 \text{ g}$

For information on how the S_s and S_1 values above have been calculated from probabilistic (risk-targeted) and deterministic ground motions in the direction of maximum horizontal response, please return to the application and select the "2009 NEHRP" building code reference document.



For PGA_M , T_L , C_{RS} , and C_{R1} values, please [view the detailed report](#).

Although this information is a product of the U.S. Geological Survey, we provide no warranty, expressed or implied, as to the accuracy of the data contained therein. This tool is not a substitute for technical subject-matter knowledge.



www.paceengrs.com

JOB NO. 16857
 JOB NAME VERTICAL LP DISPENSER
 SHEET NO. 3 OF _____
 CALCULATED BY CA DATE 10/13/16
 CHECKED BY _____ DATE _____

WIND LOADS:

$$F = q_z G C_f A \quad (\text{ASCE 7-10, EQ 29.5-1})$$

$$q_z = .00256 K_z K_{zt} K_d V^2$$

$$K_z = 1.08 \quad (h = 20 \text{ ft, EXP. D})$$

$$K_{zt} = 1.0$$

$$K_d = .95 \quad (\text{ROUND TANK})$$

$$V = 120 \text{ MPH}$$

→ USE $V = 200 \text{ MPH}$

$$q_z = .00256 (1.08)(1.0)(.95)(200)^2$$

$$= 105 \text{ PSF}$$

$$G = .85 \quad (\text{RIGID})$$

$$C_f = 0.6 \quad (\text{MODERATELY SMOOTH, } \frac{h}{D} = 7, D \sqrt{q_z} = 72.5)$$

$$F = (105 \text{ PSF})(.85)(0.6) A$$



$$= 53.6 A$$

TANK	AREA	F
1150 GAL	4' (159"/12)	= 2840 #
1250 GAL	4' (170"/12)	= 3030 #
1600 GAL	4' (218"/12)	= 3890 #

ANCHORAGE:

FBD

WIND:




NOTES:

- W/ EMPTY TANK
- 1600 GAL TANK CONTROLS BY OBSERVATION

$$T = \frac{(3890\#)(139") - .9(4040)\left(\frac{34\frac{3}{4}"}{2}\right)}{34\frac{3}{4}"}{2}$$

T = 13,740 #

SEISMIC:



NOTES:

- W/ FULL TANK
- 1600 GAL TANK CONTROLS BY OBSERVATION

$$T = \frac{2800\#(139") - [.9 - .2(.33)](10,840\#)\left(\frac{34\frac{3}{4}"}{2}\right)}{34\frac{3}{4}"}{2}$$

T = 6680 #



WIND CONTROLS: $V_u = \frac{3890\#}{4 \text{ LEGS}} = 970 \# / \text{LEG}$

$T_u = \frac{13,740\#}{2 \text{ LEGS}} = 6870 \# / \text{LEG}$

ANCHORAGE CONT:

FBD

WIND:





NOTES:

- W/EMPTY TANK
- 1600 GAL TANK CONTROLS BY OBSERVATION

$$T = \frac{3890\#(139\#) - .9(4040\#)\left(\frac{48\#}{2}\right)}{48\#}$$

$$T = 9450 \#$$

SEISMIC:



NOTES:

- W/FULL TANK
- 1600 GAL TANK CONTROLS BY OBSERVATION

$$T = \frac{(2860\#)(139\#) - [.9 \cdot .2(33)](10,840\#)\left(\frac{48\#}{2}\right)}{48\#}$$

$$T = 3590 \#$$

⇒ WIND CONTROLS: $V_u = \frac{3890 \#}{4 \text{ LEGS}} = 970 \# / \text{LEGS}$

$T_u = 9450 \# / \text{LEG}$




www.paceengrs.com

JOB NO. 10857
 JOB NAME VERTICAL LP DISPENSER
 SHEET NO. 6 OF _____
 CALCULATED BY CA DATE 10/13/16
 CHECKED BY _____ DATE _____

ANCHORAGE CONF:

CRASH POST LOADS: 6 k @ 3'
 PER NFPA 58, 2017



$$V = 1.6(6 \text{ k}) = 9.6 \text{ k}$$

$$M_u = 1.6(6 \text{ k})(3') = 28.8 \text{ k}\cdot\text{ft}$$

@ B: $V_u = \frac{9.6 \text{ k}}{2} = 4.8 \text{ k}$

$$T_u = \frac{28.8 \text{ k}\cdot\text{ft}}{4'} = 7.2 \text{ k}$$

2017 NFPA 58 §6.27.3.13

6.27.3.13 Vehicular barrier protection (VBP) shall be provided for containers serving dispensers where those containers are located within 10 ft (3 m) of a vehicle thoroughfare or parking location in accordance with 6.27.3.13(A) or 6.27.3.13(B).

(A) Concrete filled guard posts shall be constructed of steel not less than 4 in. (100 mm) in diameter with the following characteristics:

- (1) Spaced not more than 4 ft (1200 mm) between posts on center
- (2) Set not less than 3 ft (900 mm) deep in a concrete footing of not less than 15 in. (380 mm) diameter
- (3) Set with the top of the posts not less than 5 ft (900 mm) above ground
- (4) Located not less than 3 ft (900 mm) from the protected installation

(B) Equivalent protection in lieu of guard posts shall be a minimum of 3 ft (900 mm) in height and shall resist a force of 6000 lb (53.375 N) applied 3 ft (900 mm) above the adjacent ground surface.





Profis Anchor 2.6.3

www.hilti.us

Company: PACE Engineers Inc
 Specifier: 5000 Meadows Rd Suite 345
 Address: 503-597-3222 |
 Phone | Fax:
 E-Mail:

Page:
 Project:
 Sub-Project | Pos. No.:
 Date:

1
 LP Dispenser Tanks
 With Crash Post
 10/14/2016

Specifier's comments:

1 Input data

Anchor type and diameter: Hex Head ASTM F 1554 GR. 36 5/8
 Effective embedment depth: $h_{ef} = 14.000$ in.
 Material: ASTM F 1554
 Proof: Design method ACI 318-11 / CIP
 Stand-off installation: $e_b = 0.000$ in. (no stand-off); $t = 0.500$ in.
 Anchor plate: $l_x \times l_y \times t = 6.000$ in. x 12.000 in. x 0.500 in.; (Recommended plate thickness: not calculated)
 Profile: no profile
 Base material: cracked concrete, 3000, $f'_c = 3000$ psi; $h = 18.000$ in.
 Reinforcement: tension: condition B, shear: condition B;
 edge reinforcement: none or \leq No. 4 bar

5/8" ϕ ANCHORS FROM INSTALLATION GUIDE


Geometry [in.] & Loading [lb, in.lb]

WIND LOADS
 $N_u = 9450 \#$
 $V_u = 970 \#$

INTERACTION:
 $\left(\frac{9450}{15,250}\right)^{5/3} + \left(\frac{970}{10,270}\right)^{5/3} = 0.47 < 1.0 \checkmark$

LOADS SHOWN ARE FROM IMPACT.

V_u PARALLEL TO EDGE





Profis Anchor 2.6.3

www.hilti.us

Company: PACE Engineers Inc
 Specifier:
 Address: 5000 Meadows Rd Suite 345
 Phone | Fax: 503-597-3222 |
 E-Mail:

Page: 2
 Project: LP Dispenser Tanks
 Sub-Project | Pos. No.: With Crash Post
 Date: 10/14/2016

2 Load case/Resulting anchor forces


Load case: Design loads

Anchor reactions [lb]

Tension force: (+Tension, -Compression)

Anchor	Tension force	Shear force	Shear force x	Shear force y
1	3600	2400	0	2400
2	3600	2400	0	2400

max. concrete compressive strain: - [‰]
 max. concrete compressive stress: - [psi]
 resulting tension force in (x/y)=(0.000/0.000): 7200 [lb]
 resulting compression force in (x/y)=(0.000/0.000): 0 [lb]



3 Tension load

	Load N_{ua} [lb]	Capacity ϕN_n [lb]	Utilization $\beta_N = N_{ua}/\phi N_n$	Status
Steel Strength*	3600	9831	37	OK
Pullout Strength*	3600	7627	48	OK
Concrete Breakout Strength**	7200	30448	24	OK
Concrete Side-Face Blowout, direction **	N/A	N/A	N/A	N/A

* anchor having the highest loading **anchor group (anchors in tension)

3.1 Steel Strength

$N_{sa} = A_{se,N} f_{uta}$ ACI 318-11 Eq. (D-2)
 $\phi N_{sa} \geq N_{ua}$ ACI 318-11 Table D.4.1.1

Variables

$A_{se,N}$ [in. ²]	f_{uta} [psi]
0.23	58000

Calculations

N_{sa} [lb]
13108

Results

N_{sa} [lb]	ϕ_{steel}	ϕN_{sa} [lb]	N_{ua} [lb]
13108	0.750	9831	3600

X 2 ANCHORS
 = 15,250 #



Profis Anchor 2.6.3

www.hilti.us

Company: PACE Engineers Inc
 Specifier:
 Address: 5000 Meadows Rd Suite 345
 Phone | Fax: 503-597-3222 |
 E-Mail:

Page: 3
 Project: LP Dispenser Tanks
 Sub-Project | Pos. No.: With Crash Post
 Date: 10/14/2016

3.2 Pullout Strength

$$N_{pN} = \psi_{c,p} N_p \quad \text{ACI 318-11 Eq. (D-13)}$$

$$N_p = 8 A_{brg} f'_c \quad \text{ACI 318-11 Eq. (D-14)}$$

$$\phi N_{pN} \geq N_{ua} \quad \text{ACI 318-11 Table D.4.1.1}$$

Variables

$\psi_{c,p}$	A_{brg} [in. ²]	λ_a	f'_c [psi]
1.000	0.45	1.000	3000

Calculations

N_p [lb]
10896

Results

N_{pn} [lb]	$\phi_{concrete}$	ϕN_{pn} [lb]	N_{ua} [lb]
10896	0.700	7627	3600

3.3 Concrete Breakout Strength

$$N_{cbg} = \left(\frac{A_{Nc}}{A_{Nc0}} \right) \psi_{ec,N} \psi_{ed,N} \psi_{c,N} \psi_{cp,N} N_b \quad \text{ACI 318-11 Eq. (D-4)}$$

$$\phi N_{cbg} \geq N_{ua} \quad \text{ACI 318-11 Table D.4.1.1}$$

$$A_{Nc} \text{ see ACI 318-11, Part D.5.2.1, Fig. RD.5.2.1(b)}$$

$$A_{Nc0} = 9 h_{ef}^2 \quad \text{ACI 318-11 Eq. (D-5)}$$

$$\psi_{ec,N} = \left(\frac{1}{1 + \frac{2 e_N}{3 h_{ef}}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-8)}$$

$$\psi_{ed,N} = 0.7 + 0.3 \left(\frac{C_{a,min}}{1.5 h_{ef}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-10)}$$

$$\psi_{cp,N} = \text{MAX} \left(\frac{C_{a,min}}{C_{ac}}, \frac{1.5 h_{ef}}{C_{ac}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-12)}$$

$$N_b = 16 \lambda_a \sqrt{f'_c} h_{ef}^{5/3} \quad \text{ACI 318-11 Eq. (D-7)}$$

Variables

h_{ef} [in.]	$e_{c1,N}$ [in.]	$e_{c2,N}$ [in.]	$C_{a,min}$ [in.]	$\psi_{c,N}$
14.000	0.000	0.000	6.000	1.000


C_{ac} [in.]	k_c	λ_a	f'_c [psi]
-	16	1.000	3000

Calculations

A_{Nc} [in. ²]	A_{Nc0} [in. ²]	$\psi_{ec1,N}$	$\psi_{ec2,N}$	$\psi_{ed,N}$	$\psi_{cp,N}$	N_b [lb]
1370.25	1764.00	1.000	1.000	0.786	1.000	71268

Results

N_{cbg} [lb]	$\phi_{concrete}$	ϕN_{cbg} [lb]	N_{ua} [lb]
43497	0.700	30448	7200



Profis Anchor 2.6.3

www.hilti.us

Company: PACE Engineers Inc
 Specifier:
 Address: 5000 Meadows Rd Suite 345
 Phone | Fax: 503-597-3222 |
 E-Mail:

Page: 4
 Project: LP Dispenser Tanks
 Sub-Project | Pos. No.: With Crash Post
 Date: 10/14/2016

4 Shear load

	Load V_{ua} [lb]	Capacity ϕV_n [lb]	Utilization $\beta_v = V_{ua}/\phi V_n$	Status
Steel Strength*	2400	5112	47	OK
Steel failure (with lever arm)*	N/A	N/A	N/A	N/A
Pryout Strength**	4800	60896	8	OK
Concrete edge failure in direction x-**	4800	14048	35	OK

* anchor having the highest loading **anchor group (relevant anchors)

4.1 Steel Strength

$$V_{sa} = 0.6 A_{se,v} f_{uta} \quad \text{ACI 318-11 Eq. (D-29)}$$

$$\phi V_{steel} \geq V_{ua} \quad \text{ACI 318-11 Table D.4.1.1}$$

Variables

$A_{se,v}$ [in. ²]	f_{uta} [psi]
0.23	58000

Calculations

V_{sa} [lb]	7865
---------------	------

Results

V_{sa} [lb]	ϕ_{steel}	ϕV_{sa} [lb]	V_{ua} [lb]
7865	0.650	5112	2400

4.2 Pryout Strength

$$V_{cpg} = k_{cp} \left[\left(\frac{A_{Nc}}{A_{Nco}} \right) \psi_{ec,N} \psi_{ed,N} \psi_{c,N} \psi_{cp,N} N_b \right] \quad \text{ACI 318-11 Eq. (D-41)}$$

$$\phi V_{cpg} \geq V_{ua} \quad \text{ACI 318-11 Table D.4.1.1}$$

$$A_{Nc} \text{ see ACI 318-11, Part D.5.2.1, Fig. RD.5.2.1(b)}$$

$$A_{Nco} = 9 h_{ef}^2 \quad \text{ACI 318-11 Eq. (D-5)}$$

$$\psi_{ec,N} = \left(\frac{1}{1 + \frac{2 e_N}{3 h_{ef}}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-8)}$$

$$\psi_{ed,N} = 0.7 + 0.3 \left(\frac{c_{a,min}}{1.5 h_{ef}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-10)}$$

$$\psi_{cp,N} = \text{MAX} \left(\frac{c_{a,min}}{c_{ac}}, \frac{1.5 h_{ef}}{c_{ac}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-12)}$$

$$N_b = 16 \lambda_a \sqrt{f_c} h_{ef}^{5/3} \quad \text{ACI 318-11 Eq. (D-7)}$$

Variables

k_{cp}	h_{ef} [in.]	$e_{c1,N}$ [in.]	$e_{c2,N}$ [in.]	$c_{a,min}$ [in.]
2	14.000	0.000	0.000	6.000

$\psi_{c,N}$	c_{ac} [in.]	k_c	λ_a	f_c [psi]
1.000	-	16	1.000	3000

Calculations

A_{Nc} [in. ²]	A_{Nco} [in. ²]	$\psi_{ec1,N}$	$\psi_{ec2,N}$	$\psi_{ed,N}$	$\psi_{cp,N}$	N_b [lb]
1370.25	1764.00	1.000	1.000	0.786	1.000	71268

Results

V_{cpg} [lb]	$\phi_{concrete}$	ϕV_{cpg} [lb]	V_{ua} [lb]
86994	0.700	60896	4800

X 2 ANCHORS
 = 10,220 #



Profis Anchor 2.6.3

www.hilti.us

Company: PACE Engineers Inc
 Specifier:
 Address: 5000 Meadows Rd Suite 345
 Phone | Fax: 503-597-3222 |
 E-Mail:

Page: 5
 Project: LP Dispenser Tanks
 Sub-Project | Pos. No.: With Crash Post
 Date: 10/14/2016

4.3 Concrete edge failure in direction x-

$$V_{cbg} = \left(\frac{A_{Vc}}{A_{Vc0}} \right) \psi_{ec,V} \psi_{ed,V} \psi_{c,V} \psi_{h,V} \psi_{parallel,V} V_b \quad \text{ACI 318-11 Eq. (D-31)}$$

$$\phi V_{cbg} \geq V_{ua} \quad \text{ACI 318-11 Table D.4.1.1}$$

$$A_{Vc} \text{ see ACI 318-11, Part D.6.2.1, Fig. RD.6.2.1(b)}$$

$$A_{Vc0} = 4.5 c_{a1}^2 \quad \text{ACI 318-11 Eq. (D-32)}$$

$$\psi_{ec,V} = \left(\frac{1}{1 + \frac{2e_v}{3c_{a1}}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-36)}$$

$$\psi_{ed,V} = 0.7 + 0.3 \left(\frac{c_{a2}}{1.5c_{a1}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-38)}$$

$$\psi_{h,V} = \sqrt{\frac{1.5c_{a1}}{h_a}} \geq 1.0 \quad \text{ACI 318-11 Eq. (D-39)}$$

$$V_b = \left(7 \left(\frac{l_e}{d_a} \right)^{0.2} \sqrt{d_a} \right) \lambda_a \sqrt{f'_c} c_{a1}^{1.5} \quad \text{ACI 318-11 Eq. (D-33)}$$

Variables

c_{a1} [in.]	c_{a2} [in.]	e_{cV} [in.]	$\psi_{c,V}$	h_a [in.]
6.000	-	0.000	1.000	18.000
l_e [in.]	λ_a	d_a [in.]	f'_c [psi]	$\psi_{parallel,V}$
5.000	1.000	0.625	3000	2.000

Calculations

A_{Vc} [in. ²]	A_{Vc0} [in. ²]	$\psi_{ec,V}$	$\psi_{ed,V}$	$\psi_{h,V}$	V_b [lb]
240.75	162.00	1.000	1.000	1.000	6752

Results

V_{cbg} [lb]	$\phi_{concrete}$	ϕV_{cbg} [lb]	V_{ua} [lb]
20069	0.700	14048	4800

5 Combined tension and shear loads

β_N	β_V	ζ	Utilization $\beta_{N,V}$ [%]	Status
0.472	0.469	5/3	57	OK

$$\beta_{NV} = \beta_N^{\zeta} + \beta_V^{\zeta} \leq 1$$

6 Warnings

- Load re-distributions on the anchors due to elastic deformations of the anchor plate are not considered. The anchor plate is assumed to be sufficiently stiff, in order not to be deformed when subjected to the loading! Input data and results must be checked for agreement with the existing conditions and for plausibility!
- Condition A applies when supplementary reinforcement is used. The Φ factor is increased for non-steel Design Strengths except Pullout Strength and Pryout strength. Condition B applies when supplementary reinforcement is not used and for Pullout Strength and Pryout Strength. Refer to your local standard.
- Checking the transfer of loads into the base material and the shear resistance are required in accordance with ACI 318 or the relevant standard!

Fastening meets the design criteria!



Profis Anchor 2.6.3

www.hilti.us


Company: PACE Engineers Inc
 Specifier:
 Address: 5000 Meadows Rd Suite 345
 Phone | Fax: 503-597-3222 |
 E-Mail:

Page: 6
 Project: LP Dispenser Tanks
 Sub-Project | Pos. No.: With Crash Post
 Date: 10/14/2016

7 Installation data

Anchor plate, steel: -
 Profile: no profile
 Hole diameter in the fixture: $d_f = 0.688$ in.
 Plate thickness (input): 0.500 in.
 Recommended plate thickness: not calculated
 Drilling method: Hammer drilled
 Cleaning: No cleaning of the drilled hole is required

Anchor type and diameter: Hex Head ASTM F 1554 GR. 36 5/8
 Installation torque: -
 Hole diameter in the base material: - in.
 Hole depth in the base material: 14.000 in.
 Minimum thickness of the base material: 14.922 in.



Coordinates Anchor in.

Anchor	x	y	C-x	C+x	C-y	C+y
1	0.000	-4.375	6.000	-	-	-
2	0.000	4.375	6.000	-	-	-



Profis Anchor 2.6.3

www.hilti.us

Company: PACE Engineers Inc
Specifier:
Address: 5000 Meadows Rd Suite 345
Phone | Fax: 503-597-3222 |
E-Mail:

Page: 7
Project: LP Dispenser Tanks
Sub-Project | Pos. No.: With Crash Post
Date: 10/14/2016

8 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.



Profis Anchor 2.6.3

www.hilti.us

Company: PACE Engineers Inc
 Specifier: PACE Engineers Inc
 Address: 5000 Meadows Rd Suite 345
 Phone | Fax: 503-597-3222 |
 E-Mail:

Page: 1
 Project: LP Dispenser Tanks
 Sub-Project | Pos. No.: With Crash Post
 Date: 10/14/2016

Specifier's comments:

1 Input data

Anchor type and diameter: Hex Head ASTM F 1554 GR. 36 ^{5/8"}
 Effective embedment depth: $h_{ef} = 14.000$ in.
 Material: ASTM F 1554
 Proof: Design method ACI 318-11 / CIP
 Stand-off installation: $e_b = 0.000$ in. (no stand-off); $t = 0.500$ in.
 Anchor plate: $l_x \times l_y \times t = 6.000$ in. \times 12.000 in. \times 0.500 in.; (Recommended plate thickness: not calculated)
 Profile: no profile
 Base material: cracked concrete, 3000, $f'_c = 3000$ psi; $h = 18.000$ in.
 Reinforcement: tension: condition B, shear: condition B;
 edge reinforcement: none or $<$ No. 4 bar



^{5/8"} ϕ ANCHORS FROM INSTALLATION GUIDE


Geometry [in.] & Loading [lb, in.lb]

WIND LOADS:
 $N_u = 9450 \#$
 $V_u = 970 \#$

INTERACTION:

$$\left(\frac{9450}{15,250}\right)^{5/3} + \left(\frac{970}{7020}\right)^{5/3} = .49 < 1.0 \checkmark$$

LOADS SHOWN ARE FROM IMPACT





Profis Anchor 2.6.3

www.hilti.us

Company: PACE Engineers Inc
 Specifier:
 Address: 5000 Meadows Rd Suite 345
 Phone / Fax: 503-597-3222 |
 E-Mail:

Page: 2
 Project: LP Dispenser Tanks
 Sub-Project / Pos. No.: With Crash Post
 Date: 10/14/2016

2 Load case/Resulting anchor forces


Load case: Design loads

Anchor reactions [lb]

Tension force: (+Tension, -Compression)

Anchor	Tension force	Shear force	Shear force x	Shear force y
1	3600	2400	-2400	0
2	3600	2400	-2400	0

max. concrete compressive strain: - [%]
 max. concrete compressive stress: - [psi]
 resulting tension force in (x/y)=(0.000/0.000): 7200 [lb]
 resulting compression force in (x/y)=(0.000/0.000): 0 [lb]



3 Tension load

	Load N_{ua} [lb]	Capacity ϕN_n [lb]	Utilization $\beta_n = N_{ua} / \phi N_n$	Status
Steel Strength*	3600	9831	37	OK
Pullout Strength*	3600	7627	48	OK
Concrete Breakout Strength**	7200	30448	24	OK
Concrete Side-Face Blowout, direction **	N/A	N/A	N/A	N/A

* anchor having the highest loading. ** anchor group (anchors in tension)

3.1 Steel Strength

$N_{sa} = A_{se,N} f_{uta}$ ACI 318-11 Eq. (D-2)
 $\phi N_{sa} \geq N_{ua}$ ACI 318-11 Table D.4.1.1

Variables

$A_{se,N}$ [in. ²]	f_{uta} [psi]
0.23	58000

Calculations

N_{sa} [lb]
13108

Results

N_{sa} [lb]	ϕ_{steel}	ϕN_{sa} [lb]	N_{ua} [lb]
13108	0.750	9831	3600

X 2 ANCHORS
 = 15,250 #



Profis Anchor 2.6.3

www.hilti.us

Company: PACE Engineers Inc
 Specifier:
 Address: 5000 Meadows Rd Suite 345
 Phone | Fax: 503-597-3222 |
 E-Mail:

Page:
 Project:
 Sub-Project | Pos. No.:
 Date:

3
 LP Dispenser Tanks
 With Crash Post
 10/14/2016

3.2 Pullout Strength

$N_{pN} = \psi_{c,p} N_p$ ACI 318-11 Eq. (D-13)
 $N_p = 8 A_{brg} f'_c$ ACI 318-11 Eq. (D-14)
 $\phi N_{pN} \geq N_{ua}$ ACI 318-11 Table D.4.1.1

Variables

$\psi_{c,p}$	A_{brg} [in. ²]	λ_a	f'_c [psi]
1.000	0.45	1.000	3000

Calculations

N_p [lb]	10896
------------	-------

Results

N_{pn} [lb]	$\phi_{concrete}$	ϕN_{pn} [lb]	N_{ua} [lb]
10896	0.700	7627	3600

3.3 Concrete Breakout Strength

$N_{cbg} = \left(\frac{A_{Nc}}{A_{Nc0}} \right) \psi_{ec,N} \psi_{ed,N} \psi_{c,N} \psi_{cp,N} N_b$ ACI 318-11 Eq. (D-4)
 $\phi N_{cbg} \geq N_{ua}$ ACI 318-11 Table D.4.1.1
 A_{Nc} see ACI 318-11, Part D.5.2.1, Fig. RD.5.2.1(b)
 $A_{Nc0} = 9 h_{ef}^2$ ACI 318-11 Eq. (D-5)
 $\psi_{ec,N} = \left(\frac{1}{1 + \frac{2 e_N}{3 h_{ef}}} \right) \leq 1.0$ ACI 318-11 Eq. (D-8)
 $\psi_{ed,N} = 0.7 + 0.3 \left(\frac{c_{a,min}}{1.5 h_{ef}} \right) \leq 1.0$ ACI 318-11 Eq. (D-10)
 $\psi_{cp,N} = \text{MAX} \left(\frac{c_{a,min}}{c_{ac}}, \frac{1.5 h_{ef}}{c_{ac}} \right) \leq 1.0$ ACI 318-11 Eq. (D-12)
 $N_b = 16 \lambda_a \sqrt{f'_c} h_{ef}^{5/3}$ ACI 318-11 Eq. (D-7)

Variables

h_{ef} [in.]	$e_{c1,N}$ [in.]	$e_{c2,N}$ [in.]	$c_{a,min}$ [in.]	$\psi_{c,N}$
14.000	0.000	0.000	6.000	1.000


c_{ac} [in.]	k_c	λ_a	f'_c [psi]
-	16	1.000	3000

Calculations

A_{Nc} [in. ²]	A_{Nc0} [in. ²]	$\psi_{ec1,N}$	$\psi_{ec2,N}$	$\psi_{ed,N}$	$\psi_{cp,N}$	N_b [lb]
1370.25	1764.00	1.000	1.000	0.786	1.000	71268

Results

N_{cbg} [lb]	$\phi_{concrete}$	ϕN_{cbg} [lb]	N_{ua} [lb]
43497	0.700	30448	7200



Profis Anchor 2.6.3

www.hilti.us

Company: PACE Engineers Inc
 Specifier:
 Address: 5000 Meadows Rd Suite 345
 Phone | Fax: 503-597-3222 |
 E-Mail:

Page: 4
 Project: LP Dispenser Tanks
 Sub-Project | Pos. No.: With Crash Post
 Date: 10/14/2016

4 Shear load

	Load V_{ua} [lb]	Capacity ϕV_n [lb]	Utilization $\beta_v = V_{ua}/\phi V_n$	Status
Steel Strength*	2400	5112	47	OK
Steel failure (with lever arm)*	N/A	N/A	N/A	N/A
Pryout Strength**	4800	60896	8	OK
Concrete edge failure in direction x-**	4800	7024	69	OK

* anchor having the highest loading **anchor group (relevant anchors)

4.1 Steel Strength

$V_{sa} = 0.6 A_{se,V} f_{uta}$ ACI 318-11 Eq. (D-29)
 $\phi V_{steel} \geq V_{ua}$ ACI 318-11 Table D.4.1.1

Variables

$A_{se,V}$ [in. ²]	f_{uta} [psi]
0.23	58000

Calculations

V_{sa} [lb]	7865
---------------	------

Results

V_{sa} [lb]	ϕ_{steel}	ϕV_{sa} [lb]	V_{ua} [lb]
7865	0.650	5112	2400

X 2 ANCHORS
 = 10,220 #
 7020 # < 10,220 #

4.2 Pryout Strength

$V_{cp,g} = k_{cp} \left[\left(\frac{A_{Nc}}{A_{Nc0}} \right) \psi_{ec,N} \psi_{ed,N} \psi_{c,N} \psi_{cp,N} N_b \right]$ ACI 318-11 Eq. (D-41)
 $\phi V_{cp,g} \geq V_{ua}$ ACI 318-11 Table D.4.1.1
 A_{Nc} see ACI 318-11, Part D.5.2.1, Fig. RD.5.2.1(b)
 $A_{Nc0} = 9 h_{ef}^2$ ACI 318-11 Eq. (D-5)
 $\psi_{ec,N} = \left(\frac{1}{1 + \frac{2 e_{c1,N}}{3 h_{ef}}} \right) \leq 1.0$ ACI 318-11 Eq. (D-8)
 $\psi_{ed,N} = 0.7 + 0.3 \left(\frac{c_{a,min}}{1.5 h_{ef}} \right) \leq 1.0$ ACI 318-11 Eq. (D-10)
 $\psi_{cp,N} = \text{MAX} \left(\frac{c_{a,min}}{c_{ac}}, \frac{1.5 h_{ef}}{c_{ac}} \right) \leq 1.0$ ACI 318-11 Eq. (D-12)
 $N_b = 16 \lambda_a \sqrt{f_c} h_{ef}^{5/3}$ ACI 318-11 Eq. (D-7)

Variables

k_{cp}	h_{ef} [in.]	$e_{c1,N}$ [in.]	$e_{c2,N}$ [in.]	$c_{a,min}$ [in.]
2	14.000	0.000	0.000	6.000

$\psi_{c,N}$	c_{ac} [in.]	k_c	λ_a	f_c [psi]
1.000	-	16	1.000	3000

Calculations

A_{Nc} [in. ²]	A_{Nc0} [in. ²]	$\psi_{ec1,N}$	$\psi_{ec2,N}$	$\psi_{ed,N}$	$\psi_{cp,N}$	N_b [lb]
1370.25	1764.00	1.000	1.000	0.786	1.000	71268

Results

$V_{cp,g}$ [lb]	$\phi_{concrete}$	$\phi V_{cp,g}$ [lb]	V_{ua} [lb]
86994	0.700	60896	4800



Profis Anchor 2.6.3

www.hilti.us

Company: PACE Engineers Inc
 Specifier:
 Address: 5000 Meadows Rd Suite 345
 Phone | Fax: 503-597-3222 |
 E-Mail:

Page: 5
 Project: LP Dispenser Tanks
 Sub-Project | Pos. No.: With Crash Post
 Date: 10/14/2016

4.3 Concrete edge failure in direction x-

$$V_{cbg} = \left(\frac{A_{Vc}}{A_{Vc0}} \right) \psi_{ec,V} \psi_{ed,V} \psi_{c,V} \psi_{h,V} \psi_{parallel,V} V_b \quad \text{ACI 318-11 Eq. (D-31)}$$

$$\phi V_{cbg} \geq V_{ua} \quad \text{ACI 318-11 Table D.4.1.1}$$

A_{Vc} see ACI 318-11, Part D.6.2.1, Fig. RD.6.2.1(b)

$$A_{Vc0} = 4.5 c_{a1}^2 \quad \text{ACI 318-11 Eq. (D-32)}$$

$$\psi_{ec,V} = \left(\frac{1}{1 + \frac{2e_v}{3c_{a1}}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-36)}$$

$$\psi_{ed,V} = 0.7 + 0.3 \left(\frac{c_{a2}}{1.5c_{a1}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-38)}$$

$$\psi_{h,V} = \sqrt{\frac{1.5c_{a1}}{h_a}} \geq 1.0 \quad \text{ACI 318-11 Eq. (D-39)}$$

$$V_b = \left(7 \left(\frac{l_e}{d_a} \right)^{0.2} \sqrt{d_a} \right) \lambda_a \sqrt{f_c} c_{a1}^{1.5} \quad \text{ACI 318-11 Eq. (D-33)}$$

Variables

c_{a1} [in.]	c_{a2} [in.]	e_v [in.]	$\psi_{c,V}$	h_a [in.]
6.000	-	0.000	1.000	18.000
l_e [in.]	λ_a	d_a [in.]	f_c [psi]	$\psi_{parallel,V}$
5.000	1.000	0.625	3000	1.000

Calculations

A_{Vc} [in. ²]	A_{Vc0} [in. ²]	$\psi_{ec,V}$	$\psi_{ed,V}$	$\psi_{h,V}$	V_b [lb]
240.75	162.00	1.000	1.000	1.000	6752

Results

V_{cbg} [lb]	$\phi_{concrete}$	ϕV_{cbg} [lb]	V_{ua} [lb]
10034	0.700	7024	4800

5 Combined tension and shear loads

β_N	β_V	ζ	Utilization $\beta_{N,V}$ [%]	Status
0.472	0.683	5/3	82	OK

$$\beta_{NV} = \beta_N^2 + \beta_V^2 \leq 1$$

6 Warnings

- Load re-distributions on the anchors due to elastic deformations of the anchor plate are not considered. The anchor plate is assumed to be sufficiently stiff, in order not to be deformed when subjected to the loading! Input data and results must be checked for agreement with the existing conditions and for plausibility!
- Condition A applies when supplementary reinforcement is used. The Φ factor is increased for non-steel Design Strengths except Pullout Strength and Pryout strength. Condition B applies when supplementary reinforcement is not used and for Pullout Strength and Pryout Strength. Refer to your local standard.
- Checking the transfer of loads into the base material and the shear resistance are required in accordance with ACI 318 or the relevant standard!

Fastening meets the design criteria!



Profis Anchor 2.6.3

www.hilti.us

Company: PACE Engineers Inc
 Specifier:
 Address: 5000 Meadows Rd Suite 345
 Phone | Fax: 503-597-3222 |
 E-Mail:


Page:
 Project:
 Sub-Project | Pos. No.:
 Date:

6
 LP Dispenser Tanks
 With Crash Post
 10/14/2016

7 Installation data

Anchor plate, steel: -
 Profile: no profile
 Hole diameter in the fixture: $d_f = 0.688$ in.
 Plate thickness (input): 0.500 in.
 Recommended plate thickness: not calculated
 Drilling method: Hammer drilled
 Cleaning: No cleaning of the drilled hole is required

Anchor type and diameter: Hex Head ASTM F 1554 GR. 36 5/8
 Installation torque: -
 Hole diameter in the base material: - in.
 Hole depth in the base material: 14.000 in.
 Minimum thickness of the base material: 14.922 in.



Coordinates Anchor in.

Anchor	x	y	C _{-x}	C _{+x}	C _{-y}	C _{+y}
1	0.000	-4.375	6.000	-	-	-
2	0.000	4.375	6.000	-	-	-

www.hilti.us


Company: PACE Engineers Inc
Specifier:
Address: 5000 Meadows Rd Suite 345
Phone | Fax: 503-597-3222 |
E-Mail:

Page: 7
Project: LP Dispenser Tanks
Sub-Project | Pos. No.: With Crash Post
Date: 10/14/2016

8 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.

SOIL BEARING:



FDN WEIGHT:

$$(150 \text{ PCF}) (11' 6") (10' 10") (10' 10") = 26,410 \#$$

$.6D + .6W$

$$\text{KERN: } e = \frac{M}{P} = \frac{0.6(3890\#) \left(\frac{157"}{12}\right)}{.6(4040 + 26,410)} = 1.67' \text{ INSIDE KERN}$$

$$q_{\text{MAX}} = \frac{P}{A} + \frac{M}{S} = \frac{.6(4040 + 26,410)}{(10' 10")^2} + \frac{.6(3890\#) \left(\frac{157"}{12}\right)}{(10' 10") (10' 10")^2}$$

$q_{\text{MAX}} = 300 \text{ PSF} < 750 \text{ PSF}$
W/ EMPTY TANK

-OR-


$D + .6W$

$$q_{\text{MAX}} = \frac{11,200 + 26,410}{(10' 10")^2} + \frac{.6(3890\#) \left(\frac{157"}{12}\right)}{(10' 10") (10' 10")^2}$$

$q_{\text{MAX}} = 460 \text{ PSF} < 750 \text{ PSF}$
W/ FULL TANK

SOIL BEARING CONT.

SEISMIC:



.6Dt + .7E

$$\text{KERN: } e = \frac{M}{P} = \frac{.7(2800\#)\left(\frac{157}{12}\right)}{.6(11,200 + 26,410)} = 1.13' \quad \text{INSIDE KERN}$$

$$q_{\text{MAX}} = \frac{P}{A} + \frac{M}{S} = \frac{.6(11,200 + 26,410)}{(10'-10'')(10'-10'')} + \frac{.7(2800)\left(\frac{157}{12}\right)}{\frac{(10'-10'')(10'-10'')^2}{6}}$$

$$q_{\text{MAX}} = 310 \text{ PSF} < 750 \text{ PSF}$$

-OR-

Dt + .7E

$$q_{\text{MAX}} = \frac{[1 + .2(.33)](11,200 + 26,410)}{(10'-10'')(10'-10'')} + \frac{.7(2800\#)\left(\frac{157}{12}\right)}{\frac{(10'-10'')(10'-10'')^2}{6}}$$

$$q_{\text{MAX}} = 460 \text{ PSF} < 750 \text{ PSF}$$



www.paceengrs.com

JOB NO. 16857
JOB NAME VERTICAL LP DISPENSER
SHEET NO. 23 OF _____
CALCULATED BY CA DATE 10/14/16
CHECKED BY _____ DATE _____

SLIDING:

FOR COHESIVE SOILS: $C = 130$ PSF

FOR SAND/CLAYEY SAND: $\mu = .25$

$$V = .6(3890\#) = 2330\# \quad (\text{WIND})$$
$$= .7(2800\#) = 1960\# \quad (\text{SEISMIC})$$

$$V_{RES} = (10'-10'')(10'-10'')(130\text{PSF}) = 15,260\#$$

-OR-

$$V_{RES} = .25(4040\# + 26,410\#) = 7610\#$$

$$\text{FACTOR OF SAFETY: } \frac{7610\#}{2330\#} = 3.26 > 1.5 \checkmark$$


STABILITY:

$$M_{OT} = .6(3890\#) \left(\frac{157''}{12} \right) = 30,540\# \cdot ft$$

$$M_R = (4040\# + 26,410\#) \left(\frac{10'-10''}{2} \right) = 164,920\# \cdot ft$$

$$\text{FACTOR OF SAFETY: } \frac{164,920}{30,540} = 5.4 > 1.5 \checkmark$$

FDN DESIGN:



1.2D + 1.0W

KERN: $e = \frac{M}{P} = \frac{(3890 \#) \left(\frac{157"}{12} \right)}{1.2(11,200 + 26,410)} = 1.13'$

→ INSIDE KERN

$q_u = \frac{P}{A} + \frac{M}{S}$

$= \frac{1.2(11,200 + 26,410)}{(10'-10")(10'-10")} + \frac{(3890 \#) \left(\frac{157"}{12} \right)}{\frac{(10'-10")(10'-10")^2}{6}}$

$q_u = 625 \text{ PSF}$
WIND

SEISMIC:

1.2D + 1.0E

KERN: $e = \frac{M}{P} = \frac{2800 \# \left(\frac{157"}{12} \right)}{(1.2 + 2(0.33))(11,200 + 26,410)}$

$e = 0.77' < \frac{10'-10"}{6} = 1.81'$ INSIDE KERN


$q_u = \frac{P}{A} + \frac{M}{S} = \frac{[1.2 + 2(0.33)][11,200 + 26,410]}{(10'-10")(10'-10")} + \frac{2800 \# \left(\frac{157"}{12} \right)}{\frac{(10'-10")(10'-10")^2}{6}}$

$q_u = 580 \text{ PSF}$
SEISMIC

FDN DESIGN CONT:

ONE-WAY SHEAR:

$$q_u = 625 \text{ PSF}$$



$$V_u = (625 \text{ PSF})(3'-8'')(1'-0'') \left(\frac{1}{1000}\right)$$

$$V_u = 2.3 \text{ k}$$

$$\phi V_n = \phi 2 \sqrt{f'_c} b_w d = .75(2) \sqrt{3000} (12'')(14'') \left(\frac{1}{1000}\right)$$

$$\phi V_n = 13.8 \text{ k} > 2.3 \text{ k} \checkmark$$

FLEXURE:

$$M_u = (625 \text{ PSF})(1'-0'')(3'-8'') \left(\frac{3'-8''}{2}\right) \left(\frac{1}{1000}\right)$$

$$M_u = 4.2 \text{ k-ft/ft}$$

$$w/\#5 @ 12'' \text{ c/c}, T = A_s f_y = (3.1 \text{ in}^2)(60 \text{ ksi}) = 18.6 \text{ k}$$

$$a = \frac{T}{.85 f'_c b} = \frac{18.6}{.85(3)(12)} = .61''$$

$$\phi M_n = \phi T(d - \frac{a}{2}) = .9(18.6 \text{ k}) \left(14'' - \frac{.61''}{2}\right) \left(\frac{1}{12}\right)$$

$$\phi M_n = 19.1 \text{ k-ft} > 4.2 \text{ k-ft} \checkmark$$

FDN DESIGN CONT:


TWO-WAY SHEAR:

IGNORE COMPRESSION IN THESE LEGS

(WIND) (SEISMIC)

TENSION = 9450 # OR 3590 #


SEE ANCHORAGE CALCS



TOTAL COMPRESSION = 9450 + 4040 = 13,490 #
 -OR- = 3590 + 11,200 = 14,790 #

$\phi V_n = \phi 4 \sqrt{f_c'} b_o d$ $b_o = (6" + 14")(4 \text{ SIDES}) = 80"$
 $= .75(4) \sqrt{3000} (80") (14") (\frac{1}{1000})$

$\phi V_n = 184.0 \text{ K} > 14.8 \text{ K} \checkmark$



FDN PROPERTIES: $A = (10'-10")(10'-10") = 117 \text{ ft}^2$
 $S = \frac{d^3}{6\sqrt{2}} = \frac{(10'-10")^3}{6\sqrt{2}} = 149.8 \text{ ft}^3$

SOIL PRESSURE:

$q_u = \frac{P}{A} + \frac{M}{S} = \frac{1.2(37,610\#)}{117 \text{ ft}^2} + \frac{3890\# \left(\frac{152"}{12}\right)}{149.8 \text{ ft}^3}$

$q_u = 725 \text{ PSF}$



www.paceengrs.com

JOB NO. 16857
 JOB NAME VERTICAL LP DISPENSER
 SHEET NO. 27 OF _____
 CALCULATED BY CH DATE 10/14/16
 CHECKED BY _____ DATE _____

FDM DESIGN CONT:

ONE WAY SHEAR: $(725 \text{ PSF})(6'-3") = 4.5 \text{ K} < 13.8 \text{ K} \checkmark$

TWO WAY SHEAR: OK BY OBSERVATION

FLEXURE: $M_u = (725 \text{ PSF})(6'-3") \left(\frac{6'-3"}{2} \right) \left(\frac{1}{100} \right) = 14.2 \text{ K}\cdot\text{ft}/\text{ft}$

$T = A_s f_y$ w/ #5 @ 45° EA WAY, $A_s = \frac{.31}{\sqrt{2}} (2) = .44 \text{ in}^2/\text{ft}$

$= .44 (60 \text{ ksi})$

$= 26.3 \text{ K}$

$a = \frac{T}{.85 f_c' b} = \frac{26.3 \text{ K}}{.85 (3) (12")} = .86"$

$c = \frac{a}{\beta} = \frac{.86}{.85} = 1.01"$, $\frac{c}{d} = \frac{1.01"}{14"} = .07 < .375 \checkmark$
 $\Rightarrow \phi = 0.9$
 $f_s = f_y$

$\phi M_n = T (d - \frac{a}{2})$


$= .9 (26.3 \text{ K}) (14" - \frac{.86"}{2}) \left(\frac{1}{12} \right)$

$\phi M_n = 26.8 \text{ K}\cdot\text{ft} > 14.2 \text{ K}\cdot\text{ft} \checkmark$

DATE: 02-27-96

NO.	QTY	DESCRIPTION	SPEC	SUB-DWG.	NO.	QTY	DESCRIPTION	SPEC	SUB-DWG.
S1	1	.375 MIN. X 96" X 150" SHELL	SA-516-70		V6	1	1 1/4" NPT PIPE ASSEMBLY		A54421
S2	1	.375 MIN. X 95.5" X 150" SHELL	SA-516-70		SGA	1	ADAPTOR: S.G. REC. JR	SA-181-70	
H1	2	.342 MIN. X 48" O.D. 2:1 ELLIP. HEAD	SA-516-70		SGB	1	ADAPTOR: S.G. NON-REC. SENIOR	SA-181-70	
F1	1	1" NPT 1500# RADIAL FLANGE	SA-181-70		M1	4	5/8" O.D. LIFT LUG	C1010	A57563
V1A	1	2" NPT 1500# FLAT FLANGE	SA-181-70		M2	2	PIPE BRACKET: 1/4" X 7 1/2" X 34"	C1010	A7662
V1B	1	1 1/4" NPT 3000# HALF COUPLING	SA-105		M3	2	PIPE BRACKET: 1/4" X 2 3/4" X 8"	C1010	A91875
V2A	1	1 1/4" NPT 1500# FLAT FLANGE	SA-181-70		G1	1	GUARD: 3/16" X 8" X 8" X 18 3/4"	C1010	A53791
V2B	1	3/4" NPT 3000# TOE COUPLING	SA-105		G2	2	GUARD CLIP	C1010	A54793
V3	1	3/4" NPT PIPE ASSEMBLY		A59106	S3	4	ANGLE LEG ASY: 1/2" X 4" X 34 75"	C1010	A72900
V4	1	1 1/4" NPT PIPE ASSEMBLY		A54419	T1	1	TOP TAB	C1010	V12510
V5	1	3/4" NPT PIPE ASSEMBLY		A54420	NP	1	ASME DATA PLATE	C1010	A77447

APPROVED
RELEASED FOR PRODUCTION
DATE



- NOTES CONT:
- BEFORE SHIPPING :
 - INSTALL A85180 SHIPPING COVER ON SR SG ADAPTER W/ A85182 BOLTS.
 - INSTALL STEEL PLUGS IN ALL OPENINGS.
 - ATTACH SHIPPING BRACE A55742.


SYM	DATE	BY	REVISION	APP	XREF	REV	NOTES	SPECIFICATIONS
D	05-96	SE	REV'D X-RAY SPEC., RMV'D X-RAY NOTE, 388 SH WAS .375	JD			1. KEEP SIGHT GAUGES IN VERTICAL ALIGNMENT. 2. ALL VALVES AND GAUGES TO BE BOXED AND LABELED, THEN STRAPPED TO SHIPPING BRACE. 3. AIR TEST ALL LINES INTO VAPOR SPACE BEFORE HEAD-UP, AFTER ALL WELDING ON INSIDE OF TANK IS COMPLETED. 4. BEFORE SHIPPING : A) INSTALL A85179 SHIPPING COVER ON JR SG ADAPTER W/ A85181 BOLTS.	SH.375 MAT.LSA-516-70 LGR.218 SH.450 F HD.342 MAT.LSA-516-70 PSI @ 250 PSI GAL.1600 SA.236 RT-4 ADMIT -20°F @ 250 PSI WT.4039# CU.FT.213.9 EXAM UC20(f) TEST 325 PSI CORR ALW --- SH --- HD XRAY SPOT W CODE: ASME SEC. VIII DIV. 1 CRN N/A WELD DETAILS: M-1932 STD. TOLERANCES (UNLESS OTHERWISE NOTED): M-2461
20	07-96	LB	ADDED NOTE #4, DET.'G' WAS DET.'E', ADDED TACK WELD DTL	AS				
21	03-02	LB	REV'D NOTE #4	AS				
E	02-05	ECB	FORMAT UPDATED, RMV'D NOTE 5, REV'D LEG WELDS, ADDED M3 PIPE BRACES, REV'D PIPES, WT WAS 4246#	ECB				
F	8-06	AW	SHELL MATERIAL WAS .387 SA-455, TEMP. WAS 650F	AW				



MANCHESTER
VERTICAL LP DISPENSER
1600 GAL W.C.

DATE: 07-07-96
SCALE: NONE
DRAWING NO.: 29016

DATE: 02-27-96
DRAWN BY: SE
APP. BY: JS



NO. QTY.	DESCRIPTION	SPEC	SUB-DWG.	NO. QTY.	DESCRIPTION	SPEC	SUB-DWG.
S1 1	.356 MIN. X 96" X 149 3/4" SHELL	SA-455		SGA 1	ADAPTOR: S.G. REC. JR	SA-181-70	
S2 1	.356 MIN. X 48 1/4" X 149 3/4" SHELL	SA-455		SGB 1	ADAPTOR: S.G. NON-REC. SENIOR	SA-181-70	
H1 2	.301 MIN. X 48" O.D. 21 ELLIP. HEAD	SA-516-70		M1 4	5/8" O.D. LIFT LUG	A57563	
F1 1	1" NPT 1500# FLAT FLANGE	SA-181-70		M2 2	PIPE BRACKET: 1/4" X 7 1/2" X 34"	A77662	
V1A 1	1 1/4" NPT 1500# FLAT FLANGE	SA-181-70		M3 2	PIPE BRACKET: 1/4" X 2 3/4" X 8"	A91875	
V1B 1	1 1/4" NPT 3000# HALF COUPLING	SA-105		G1 1	GUARD: 3/16" X 8" X 8" X 18 3/4"	A55791	
V2 1	1 1/4" NPT 1500# FLAT FLANGE	SA-181-70		G2 2	GUARD CLIP	A54793	
V3 1	3/4" NPT PIPE ASY.	A78001		S3 4	ANGLE LEG ASY: 3/8" X 4" X 4" X 34 1/2"	A77993	
V4 1	1/4" NPT PIPE ASY.	A78002		T1 1	TOP TAB	V12510	
V5 1	3/4" NPT PIPE ASY.	A77990		NP 1	ASME DATA PLATE	A77447	
V6 1	1 1/4" NPT PIPE ASY.	A79988					

STAMP DATE	BY	REVISION	APP. XREF. REV.	NOTES	SPECIFICATIONS	DATE	SCALE	DRAWING NO.
12-07-98	AS	.387 WAS .388 SHELL			SH. 356 MATL. SA-516-70	07-28-96	NONE	29011
13-03-02	LB	REV'D NOTE #4, ADDED NOTE #5			HT. 301 MATL. SA-516-70			
C	02-09-98	FORMAT UPDATED, ADDED M3, REV'D LEG WELD, REV'D NOTE #5, TEST PRESSURE WAS 37PSI, PIPES REV'D, WT WAS 3399#			GA. 1250 S.A. 187			
D	05-05-99	DIM. FOR M2 & M3 WAS 25 1/4"			RT-4 WMT -2010 250 PSI			
E	8-06-99	SHELL MATERIAL WAS .387 SA-455, TEMP. WAS 650F			EXMT UG20(G) TEST 325 PSI			
F	7/16/13	PRE CHANGED LONGSEAM WELD SYMBOLS TO SHOW S1652			CRK N/A			

WINGMASTER
RED 1/16" (2000)

VERTICAL LP DISPENSER
1250 GAL W.C.


DATE: 07-28-96
SCALE: NONE
DRAWN BY: SE
DATE: 06-10-96
APP. BY: JD

NOTES CONT:
 4. BEFORE SHIPPING :
 B) INSTALL AB5180 SHIPPING COVER ON SR SG ADAPTER W/ AB5182 BOLTS.
 C) INSTALL STEEL PLUGS IN ALL OPENINGS.
 D) ATTACH SHIPPING BRACE AS5742.

APPROVED FOR PRODUCTION
 CODE/ADDENDA
 RELEASED FOR PRODUCTION
 BPT

APPROVED FOR PRODUCTION
 RELEASED
 CODE/ADDENDA
 V.0

NO. QTY	DESCRIPTION	SPEC	SUB-DWG.	NO. QTY	DESCRIPTION	SPEC	SUB-DWG.
S1	1 .356 MIN. X 96" X 150" SHELL	SA-516-70		SBA	1 ADAPTOR: S.G. REC. JR.	SA-181-70	
S2	1 .301 MIN. X 37 1/4" X 150" SHELL	SA-516-70		SGB	1 ADAPTOR: S.G. NON-REC. SENIOR	SA-181-70	
H1	2 .301 MIN. X 48" O.D. 2:1 ELLIP. HEAD	SA-516-70		M1	4 5/8" O.D. LIFT LUG	A57563	
F1	1 1" NPT 1500# FLAT FLANGE	SA-181-70		M2	2 PIPE BRACKET: 1/4" X 7 1/2" X 3/4"	A77862	
V1A	1 1/4" NPT 1500# FLAT FLANGE	SA-181-70		M3	2 PIPE BRACKET: 1/4" X 2 3/4" X 8"	A91875	
V1B	1 1/4" NPT 3000# HALF COUPLING	SA-105		G1	1 GUARD: 3/16" X 8" X 8" X 18 3/4"	A5791	
V2	1 1/4" NPT 1500# FLAT FLANGE	SA-181-70		G2	2 GUARD CLIP	A54793	
V3	1 3/4" NPT PIPE ASY.	A72905		S3	4 ANGLE LEG ASY: 3/8" X 4" X 4" X 34 1/2"	A77893	
V4	1 1/4" NPT PIPE ASY.	A72903		T1	1 TOP TAB	V12510	
V5	1 3/4" NPT PIPE ASY.	A72904		NP	1 ASME DATA PLATE	A77447	
V6	1 1/4" NPT PIPE ASY.	A72902					



NOTES CONT. 4. BEFORE SHIPPING :
 B) INSTALL AB5180 SHIPPING COVER ON SR S6 ADAPTER W/ AB5182 BOLTS.
 C) INSTALL STEEL PLUGS IN ALL OPENINGS.
 D) ATTACH SHIPPING BRACE A55742.

DATE	BY	REVISION
		REDESIGNED FOR PRODUCTION
		OUTSIDE WAS FROM ROUND SEAM, WT WAS 2878#
		RMD PIPE CLIPS, ADDED W2 & W3 BRACES, REV'D PIPES, WT WAS 2875#
		SHELL MATERIAL WAS 307 SA-105, TAP WAS 607 W/ 1/4" DIA. HOLE
		CHANGED ANGLE LEG BRACKET MATERIAL THICKNESS

APPREEF REV
 ECRB
 ECRB
 AW
 J.C


NOTES
 1. KEEP SIGHT GAUGES IN VERTICAL ALIGNMENT.
 2. ALL VALVES AND GAUGES TO BE BOXED AND LABELED, THEY STRAPPED TO SHIPPING BRACE.
 3. AIR TEST ALL LINES INTO VAPOR SPACE BEFORE HEAD-UP, AFTER ALL WELDING ON INSIDE OF TANK IS COMPLETED.
 4. BEFORE SHIPPING :
 A) INSTALL AB5179 SHIPPING COVER ON JR S6 ADAPTER W/ AB5181 BOLTS.

SPECIFICATIONS
 O.D. 48
 LGTH. 159
 WT. 250
 PSI @ 400'-F
 RT-4 UNIT -20 TO 250 PSI
 EXM U2X(0) TEST 325 PSI
 CORR ALY --- SH --- HD
 CODE ASME SEC. VIII DIV. 1
 WELD DETAILS: M-1832
 STD. TOLERANCES (UNLESS OTHERWISE NOTED): M-24E1

VERTICAL LP DISPENSER
 1150 GAL. W.C.
 DATE 06-03-92
 DRAWN BY DN
 SCALE: NONE
 DATE 06-16-92
 APP. BY US
 DRAWING NO. 22014


CRASH POST ASSEMBLY

SHEET: 31




INSTALLATION DETAILS

FIGURE-18A




LAYOUT BASE/BEAM ASY.



GROUTING DETAIL

CRASH POST BASE
BY MANCHESTER TANK,
CENTERED UNDER TANK.

VERTICAL DISPENSER TANK
BY MANCHESTER TANK
CENTERED ON SLAB



PLAN


SEE ASSEMBLY INSTRUCTIONS
BY MANCHESTER TANK
FOR BOLT INFORMATION

#5 REBAR @ 12' O.C.
EA. WAY TOP & BOTTOM

CRASH POST ASSEMBLY NOT
SHOWN FOR CLARITY

(2) 3/4"Ø F1554 GR. 36
CAST-IN PLACE BOLTS
PER BASE PLATE

(2) STANDARD NUTS AND
PL WASHER 1/4"x6x6
AT END OF EACH BOLT



NOTES:

1) FOR FROST DEPTH GREATER THAN THICKNESS OF SLAB, REFER TO DETAIL 2/SK2. INQUIRE TO LOCAL JURISDICTION FOR REQUIRED MIN FROST DEPTH

2) FOUNDATION THICKNESS MAY BE REDUCED TO 1'-6" FOR 1150 GAL AND 1250 GAL VERTICAL LP DISPENSER TANKS.

ELEVATION

FOUNDATION SKETCH 1



SCALE: N.T.S.



5000 Meadows Road Suite 345
Lake Oswego, OR 97035
p. 503.597.3222 | f. 503.597.7655
Civil | Structural | Planning | Survey
paceengrs.com

PROJECT:

MANCHESTER TANK

DATE:

01/19/2017

PROJECT NO:

16857

DRAWING TITLE:


1600 GAL. VERTICAL DISPENSER
TANK FOUNDATION

FILE NO:

-

SHEET:

SK1 of 2



NOTES:

- 1) FOUNDATION CAN BE MONO-POURED AS AN ALTERNATIVE.
- 2) $f'c = 3000$ PSI
 $F_y = 60$ KSI
 $q_u = 1500$ PSF

2
SK2

TYP SLAB W/ HIGH FROST DEPTH

SCALE: N.T.S.

	5000 Meadows Road Suite 345 Lake Oswego, OR 97035 p. 503.597.3222 f. 503.597.7655	PROJECT: MANCHESTER TANK	DATE: 01/18/2017	PROJECT NO: 16857
	Civil Structural Planning Survey paceengrs.com	DRAWING TITLE: TYPICAL SLAB W/ HIGH FROST DEPTH	FILE NO: -	SHEET: 2 OF 2