


- NOTES:
1. ALL STORM SEWER, SANITARY SEWER, AND WATER MAIN MATERIALS AND INSTALLATION PER APPLICABLE SECTIONS OF THE LATEST EDITIONS OF THE STANDARD SPECIFICATIONS FOR SEWER AND WATER CONSTRUCTION IN WISCONSIN, WISCONSIN ADMINISTRATIVE PLUMBING CODE AND THE CITY OF WAUKESHA REQUIREMENTS.
 2. ALL TRENCHES IN PAVEMENT AREAS SHALL HAVE GRAVEL BACKFILL.
 3. EXACT SIZE AND LOCATION OF SANITARY AND WATER SERVICE TO PROPOSED BUILDINGS BY PLUMBING CONSULTANT/CONTRACTOR.
 4. PROPOSED WATER MAIN SHALL HAVE A MINIMUM 6 FEET OF COVER.
 5. THE CONTRACTOR SHALL VERIFY ALL SEWER AND WATER CONNECTIONS PRIOR TO UTILITY CONSTRUCTION. NOTIFY THE ENGINEER WITH ANY DISCREPANCIES.
 6. THE PROPOSED STORM SEWER HAS BEEN DESIGN TO HANDLE THE 100-YEAR STORM EVENT.
 7. UNUSED WATER SERVICE STUBS TO THE PROPERTY SHALL BE ABANDONED BY PLUGGING AT THE WATER MAIN AND THE VALVE BOX ABANDONED.
 8. ALL PUBLIC ROADWAY OPENINGS FOR UTILITY CONNECTIONS SHALL BE SAWCUT FULL DEPTH AND REPLACE CURB & GUTTER, PAVEMENT, ETC. IN KIND.
 9. ALL DOWNSPOUTS SHALL SPILL TO GRADE



Mechanical Room

CJE NO.: 1155R9
FEBRUARY 05, 2013
REV. 08-08-13
REV. 09-06-13
REV. 10-07-13

MSP WAUKESHA
WAUKESHA, WI