February 21, 2022

Doug Koehler Principal Planner City of Waukesha 201 Delafield Street Waukesha, WI 53188

Re:

Tallgrass Villas SPAR21-00063

City Review #1

Attn: Mr. Koehler



This response letter is in reference to your Tallgrass Villas Review Letter No. 1 dated January 6th, 2022. For brevity sake, only the responses are listed here.

<u>Erosion Control – David Buechl</u>

1. Note has been added; Erosion Control Notes #15, Sheet C3.0

Stormwater - David Buechl

- 1. The grading has been updated in several areas to ensure positive flow away from buildings and to minimize adverse impacts on adjacent properties.
 - a. The overland flow route has been labeled. See Sheet C2.0 The flow height as been determined. See Appendix F of the SWMP.
 - b. The 10-Year and 100-Year pond elevations have been labeled for each biofiltration basin
 - c. Storm sewer drainage maps are now included with the calculations.
 - d. We have heard something similar.
- 2. The City storm water design checklist has been submitted.
- 3. Discharge pipes near the sanitary sewer easement have been moved out of the easement and there is now grading to direct the water past the manholes.
- 4. Done
- 5. Bielinski will be providing the landscape plan.
- 6. The wet pond has been replaced by another bio-retention basin.
- 7. All plans and supporting documents have been stamped.
- 8. A table has been included showing that the buildings are at least 1 foot above the bedrock or groundwater. See Sheet C2.0
- 9. A SWMA has been included.
 - a. The SWMA uses the City's template
 - b. The SWMA exhibits a to c will be recorded after they are approved by the City.
- 10. None
- 11. Note added to storm water pond detail sheets C2.1 C2.3.
- 12. Similar comment as Erosion Control #1. Note added. See Erosion Control Notes #15, Sheet C3.0

Addressing - Megan Roessler

Noted

- 2. Noted
- 3. Street names have been determined and are shown on the plans
- 4. The streets are labeled as private streets; See Sheet C1.0
- 5. The street names are shown on the plans.

<u>General Engineering – David Buechl</u>

- 1. Permits
 - a. We (possibly the contractor) will be applying for the City Erosion Control Permit
 - b. We will be applying for a Chp 30 / NOI joint grading permit from WDNR
 - c. We will be applying for a Chp 30 / NOI joint grading permit from WDNR
 - d. We have the wetland concurrence letter for the August 4th 2017 wetland delineation from Stantec. A copy is enclosed.
 - e. The sanitary sewer will be a private interceptor sewer and therefore a plumbing permit will be applied for with DSPS, not WDNR.
 - f. Yes we will apply for a plumbing permit with DSPS.
 - g. We will apply for a City of Waukesha Construction Permit for working in the right-ofway.
- 2. Building Permits
 - a. A CSM is forthcoming that will show the boundary, dedicate land or an easement for the culvert, and will create the easements for water and sewer.
 - b. Bielinski will be providing the developer's agreement
 - c. Noted
 - d. Noted
 - e. Noted
 - f. N/A
 - g. Noted
 - h. A CSM will be prepared.
- 3. Noted

Site Plan

- 1. Similar to my answer for Building Permits #2a above, a CSM is forthcoming that will show this create this easement. Note that this proposed easement is shown on Sheet C1.0
- 2. Updated checklists are included.
- 3. We have added updated survey of Northview to the drawings and have modified the design accordingly.
- 4. CBU locations are shown on the site plan Sheet C1.0.
- 5. The driveway onto Northview meets these requirements.
 - a. No variance for the driveway opening is needed.
 - b. Overall driveway width is labeled on Sheet C1.0.

Planning - Doug Koehler

- 1. The revised architectural plans are included.
- 2. Yes, it is shown on Sheet C1.0
- 3. All buildings are now 25' from the private road.
- 4. A project Narrative is included in the submittal.
- 5. Bielinski will be providing the landscape plan.
- 6. Bielinski will be providing the landscape plan.
- 7. Noted

8. Bielinski will be providing the Lighting Plan.

Water Utility - Chris Walters

1. Watermain on Northview now shown correctly

If you have any questions please feel free to contact me.

Sincerely,

TRIO ENGINEERING, LLC

Paul Jenswold, P.E.