

Project Reviews

City of Waukesha

Project Number: SPAR23-00025

Description: **Minor Site Plan - 307 E. Main St**

Applied: **6/29/2023**

Approved:

Site Address: **307 E MAIN ST**

Closed:

Expired:

City, State Zip Code: **WAUKESHA, WI 53186**

Status: **RECEIVED**

Applicant: **Matthew Stafford, Vincent James Mentoring**

Parent Project:

Owner: **STEPHEN GREEN**

Contractor: **<NONE>**

Details:

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: ALL						
7/17/2023		7/18/2023	SANITARY SEWER	Chris Langemak		
Notes:						
Review Group: AUTO						
6/29/2023		7/20/2023	Building Inspection	KRISTIN STONE		
Notes:						
6/29/2023	6/30/2023	7/14/2023	Fire	Brian Charlesworth	REVIEW COMPLETE	
Notes:						
6/29/2023	7/17/2023	7/14/2023	General Engineering	DAVID BUECHL	ADDITIONAL INFO REQUIRED	see notes
Notes:						
1. Provide financial guarantee for landscaping, if landscaping required by Council.						
6/29/2023		7/14/2023	Parks	Melissa Lipska		
Notes:						
6/29/2023	7/18/2023	7/14/2023	Planning	CHARLIE GRIFFITH	REVIEW COMPLETE	
Notes:						
<ul style="list-style-type: none"> Grass buffer must be added to at least five feet back from the sidewalk throughout the parking area. Outdoor storage of items not related to the approved uses, or necessary for construction, specifically including the semi-trailer currently stored on the site, will be removed prior to issuance of building permits and will not be returned to the property. 						

Project Reviews

City of Waukesha

6/29/2023	7/13/2023	7/14/2023	Water Utility	Chris Walters	APPROVED	No comments
Notes:						