



City of Waukesha
 Department of Public Works
 130 Delafield Street
 Waukesha, WI 53188
 Waukesha-wi.gov

Stormwater Management Plan

Attachment D
 (Rev 04/18)

Project Name: New Perspective Waukesha

Engineer & Design Firm: The Sigma Group, Inc

STORM WATER MANAGEMENT PLAN WORKSHEET			
<p>The City of Waukesha requires a Stormwater Management Plan to be submitted with the proposed development plans for site plan review. A Stormwater Management Plan is a document describing the storm water management practices constructed and implemented within the proposed development to ensure compliance with the storm water management criteria, as set forth by the City of Waukesha. The purpose of a Stormwater Management Plan is to protect the safety and health of the public, property and aquatic environment from the threats due to storm water from land development activity. The worksheet will provide a basis to the information that shall be provided when preparing a Stormwater Management Plan for a proposed development. This Plan shall include a set of complete plans and calculations, stamped by a registered professional engineer. Stormwater Management Plans are required as listed in City Code Book Chapter 32.06(b)</p>			
Exemptions for Design and Plan Requirements			
YES	NO	N/A	
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Site is associated with agricultural or silvicultural activities
Design Requirements: Total Suspended Solids			
YES	NO	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Site is a New Development – 80% Reduction must be met
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Site is an Infill Development – 80% Reduction must be met
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Site is a Redevelopment – 40% Reduction must be met
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Site has areas of New Development and Redevelopment
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Calculations for % Reduction are included in the plan (WinSLAMM input and output)
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Storm water Management Facilities to address TSS removal are designed according to Chapter 32 of the City Code Book and DNR Technical Standards – Check all that apply: <ul style="list-style-type: none"> <input type="checkbox"/> Wet Detention Basin <input checked="" type="checkbox"/> Bio Retention Basin <input type="checkbox"/> Swales <input type="checkbox"/> Proprietary Devices <input checked="" type="checkbox"/> Other (specify): <u>Infiltration Basin</u>
Design Requirements: Peak Discharge			
YES	NO	N/A	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Storm water Management Facilities to address Peak Discharge are designed according to Chapter 32 of City Code Book and DNR Technical Standards – Check all that apply: <ul style="list-style-type: none"> <input type="checkbox"/> Wet Detention Basin <input checked="" type="checkbox"/> Bio Retention Basin <input type="checkbox"/> Swales <input checked="" type="checkbox"/> Other (specify): <u>Infiltration Basin</u>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Downstream Capacity for 2-year, 10-year and 100-year, 24-hour Design Storms are met
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Calculations of available capacity, proportional share, and proposed utilized capacity under all design storms are included in plan
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Calculations of Peak Discharge are included in the plan

Design Requirements: Infiltration			
YES	NO	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Hydraulic Soil Type: <input type="checkbox"/> Soil Type A – Proceed <input type="checkbox"/> Soil Type B – Proceed <input type="checkbox"/> Exemption or Exclusion – Provide documentation
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Low Imperviousness. Ex: low density residential parks, cemeteries Post-Development Infiltration Performance Standards: <input type="checkbox"/> Up to 40% Connected Impervious Surface <input checked="" type="checkbox"/> 90% of Pre-Development Infiltration volume met <i>cr 25% post development volume</i> <input type="checkbox"/> 1% of site – Maximum Effective Infiltration Area
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Medium Imperviousness. Ex: Medium and high density residential, multi-family, industrial, institutional, office park. Post-Development Infiltration Performance Standards: <input type="checkbox"/> 40%-80% Connected Impervious Surface <input type="checkbox"/> 75% of Pre-Development Infiltration volume met <input type="checkbox"/> 2% of site – Maximum Effective Infiltration Area
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	High Imperviousness. Ex: commercial strip malls, shopping centers, commercial downtowns Post-Development Infiltration Performance Standards: <input type="checkbox"/> Greater than 80% Connected Impervious Surface <input type="checkbox"/> 60% of Pre-Development Infiltration volume met <input type="checkbox"/> 2% of site – Maximum Effective Infiltration Area
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Site has parking lots and new road construction: <input checked="" type="checkbox"/> Pretreatment included <input checked="" type="checkbox"/> 10% Infiltration of the runoff from the tow-year, 24-hour design storm with Type II Distribution
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Calculations of Infiltration Volumes are included in the plan and model input and output (WinSLAMM)
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Exclusions for Infiltration: <input type="checkbox"/> Tier 1 Industrial Facility <input type="checkbox"/> Storage and Loading Areas of Tier 2 Industrial Facility <input type="checkbox"/> Fueling and Vehicle Maintenance Facility <input type="checkbox"/> Areas within 1,000 feet up gradient of Karst Features <input type="checkbox"/> Areas within 100 feet downgradient of Karst Features <input type="checkbox"/> Areas with < 3 feet of separation from bottom of Infiltration System to seasonal high groundwater or top of bedrock (does not prohibit roof runoff) <input type="checkbox"/> Areas with runoff from industrial, commercial and institutional parking lots and roads with < 5 feet separation from bottom of infiltration system to elevation of seasonal high groundwater or top of bedrock <input type="checkbox"/> Areas within 400 feet of community water system well <input type="checkbox"/> Areas within 100 feet of private well <input type="checkbox"/> Areas where contaminants of concern (defined by NR720.03(2) are present in the soil through which infiltration will occur) <input type="checkbox"/> Area where soil does not meet any of the following characteristics between bottom of infiltration system and seasonal high groundwater and top of bedrock: <input type="checkbox"/> At least 3-foot soil layer with 20% fines or greater <input type="checkbox"/> At least 5-foot soil layer with 10% fines or greater

YES	NO	N/A	
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Exemptions for Infiltration: <ul style="list-style-type: none"> <input type="checkbox"/> Areas where infiltration rate < 0.6 inches/hour <input type="checkbox"/> Parking Areas and Access Roads less than 5,000 square feet for commercial and industrial <input type="checkbox"/> Redevelopment Post-Construction Sites <input type="checkbox"/> Infill Development < 5 acres <input type="checkbox"/> Infiltration during periods when soil on the site is frozen <input type="checkbox"/> Roads in commercial, industrial and institutional land uses <input type="checkbox"/> Arterial Roads in Residential land uses
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Storm water Management Facilities to address Infiltration are designed according to Chapter 32 of the City Code Book and DNR Technical Standards – Check all that apply: <ul style="list-style-type: none"> <input checked="" type="checkbox"/> Bio Retention Basin <input checked="" type="checkbox"/> Infiltration Basin/Rain Garden <input type="checkbox"/> Infiltration Trench <input type="checkbox"/> Other (specify): _____
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Soil and Site Evaluation Report per DNR Technical Standards.
Design Requirements: Protective Areas			
YES	NO	N/A	
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Impervious areas are outside protective area. If not, provide a written explanation.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Land disturbing activities are within a protective area. If Yes , check all that apply: <ul style="list-style-type: none"> <input type="checkbox"/> If no impervious area is within protective area, adequate sod or self-sustaining vegetative cover of 70% or greater shall be established. <input type="checkbox"/> Adequate sod or self-sustaining vegetative cover is sufficient for bank stability, maintenance of fish habitat and filtering of pollutants from upslope overland flow areas under sheet flow conditions. <input type="checkbox"/> Non-Vegetative materials are employed on the bank as necessary to prevent erosion (steep slopes, high velocity areas).
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Best Management Practices are located within the protective area – Check all that apply: <ul style="list-style-type: none"> <input type="checkbox"/> Filter Strips <input type="checkbox"/> Swales <input type="checkbox"/> Wet Detention Basins <input type="checkbox"/> Other (specify): _____
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Non-Applicable Areas Apply: <ul style="list-style-type: none"> <input type="checkbox"/> Structures that cross or access surface water (boat landing, bridge, culvert) <input type="checkbox"/> Structures constructed in accordance with Section 59.692(1v) Wisconsin Statutes: <input type="checkbox"/> Post-Construction Runoff does not enter surface water except to the extent that vegetative groundcover necessary for bank stability
Design Requirements: Fuel and Maintenance Facilities			
YES	NO	N/A	
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Are Fuel and Maintenance Facilities on the Site?
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Are Best Management Practices designed to reduce petroleum within runoff (no visible sheen)?

Design Requirements: Swale Treatment for Transportation Facilities			
YES	NO	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<p>Does the site use swales for runoff conveyance and pollutant removal for transportation facilities? If Yes, must have the following:</p> <p><i>Groundcover:</i></p> <p><input checked="" type="checkbox"/> Vegetated</p> <p><input type="checkbox"/> Non-Vegetated where appropriate to prevent erosion or provide runoff treatment (riprap, check dams)</p> <p><i>Swale Velocity Control:</i></p> <p><input type="checkbox"/> Swale is 200 feet or more in length with a velocity no greater than 1.5 feet per second for the two-year, 24-hour design storm or two-year storm with duration equal to time of concentration</p> <p><input type="checkbox"/> Swale is 200 feet or more in length with velocity > 1.5 feet per second then velocity is reduced to maximum extent practicable. Written explanation stating why requirement of > 1.5 feet per second cannot be met</p>
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<p>Exemptions Apply:</p> <p>Average Daily Vehicles > 2,500 and initial surface water of the state that runoff directly enters is any of the following:</p> <p><input type="checkbox"/> An outstanding resource of water (ORW)</p> <p><input type="checkbox"/> An exceptional resource water (ERW)</p> <p><input type="checkbox"/> Water is listed in Section 303(d) of the Federal Clean Water Act and is identified as impaired in whole or in part due to non-point source impacts</p> <p><input type="checkbox"/> Water where targeted performance standards are developed under NR 151.004 of the Wisconsin Administrative Code to meet water quality standards</p>
Plan Requirements			
YES	NO	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Provide permit application form, including contact information (name, address, telephone number) for the landowner, developer, land operator, certified project engineering, responsible party for installation of storm water management practices, responsible party for long-term maintenance of the storm water management practices.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Legal Description of proposed development. <i>On Maint. Agreement</i>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Narrative describing the proposed development.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Brief summary of Design Criteria and methods used for development of Storm Water Management Practices.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Storm Water Management Maintenance Agreement shall be included with the Storm Water Management Plan (see Storm Water Management Maintenance Agreement template for additional information required). <i>To be provided separately</i>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Certification by a Wisconsin registered professional engineer.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Financial Guarantee.

Description and Site Characteristics for Pre/Post Development conditions shall be delineated by one (1) or more site maps at a scale of not less than one (1") inch equals two hundred (200') feet. The map(s) shall include, at minimum, the following information:

YES	NO	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Site Location and Legal Description.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pre-developed and revised topography by contours related to USGS survey datum or other datum approved by City. The topographic contours of the site shall not exceed 2 feet. The topography shall extend at minimum 100 feet outside the site boundaries to show runoff patterns onto, through and from the site.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	One hundred (100) year Floodplain boundary, shore land, environmental corridors, and wetland boundaries shall be delineated if applicable
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	All lakes, streams, and other water bodies illustrated on map shall be named as defined on a USGS 7.5 minute topographic map.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Predominant Soil Types and Hydraulic Soil Group Classifications.
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	State Plane coordinates of all manhole and inlets with reference to two nearest reference point monuments which shall be Section or ¼ Section corners.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Location, capacity, and dimensions/details of on-site Pre-developed and Post-developed storm water management facilities such as, but not limited to, the following: manholes, pipes, curbs, gutters, curb inlets, filter strips, swales, detention basins, curb cuts, and drainage gates.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Location, extent, detailed drawings, typical cross sections and slope ratios of all pre-developed and post-developed storm water retention and detention areas and drainage ways – list inlet/outlet elevations, permanent water surface elevation, high water surface elevation, and emergency spillway elevation, if applicable.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Location and Elevations at top and bottom of pre-developed and post-developed buildings and structures.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Locations and names of pre-developed and post-developed streets and intersections and the location of parking lots, sidewalks, bike paths and impervious surfaces (excluding single family residences). Map(s) shall clearly differentiate pre-developed and post-developed surfaces.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Delineation and dimensions of all pre-developed and post-developed property boundaries, easements, right-of-way, building setbacks, maintenance easements, and other restrictions.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pre-developed and post-developed land use boundaries, including cover type and condition.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Post-developed land use cover totals for Impervious and Pervious areas as well as permanent water surface area of all storm water management facilities.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Delineation of pre-developed and post-developed watershed and sub-watershed boundaries used in determination of Peak flow discharges and discharge volumes from the site. (If the watershed extends beyond the site boundaries, a separate watershed map can be supplied).
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Location of the pre-developed and post-developed discharge points.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pre/Post developed directional Flow Paths used to calculate existing/proposed time of concentrations.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Location of the Emergency Overland Flow.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Location of any Regional Treatment Options (if applicable).
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Identify all pre-developed land cover features, such as, natural swales, natural depressions, native soil infiltrating capacity and natural groundwater recharge areas.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Location of any protective areas within the site.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Location of wells located within 1,200 feet of pre-developed and post-developed Storm Water Detention Basins, Infiltration Basins, or Infiltration Trenches.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Delineation of Wellhead protection areas defined under NR 811.16

Supportive Information and Calculation summaries shall be supplied for all storm water management requirements as dictated in the checklist under Design Requirements:

YES	NO	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pre-developed and post-developed watershed, sub-watersheds, and land use areas (acres, watershed shall be delineated by property lines).
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pre-developed and post-developed impervious areas (acres).
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pre-developed and post-developed Runoff Curve Numbers.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pre-developed and post-developed Time of Concentration.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pre-developed and post-developed peak flows for the 2-year, 10-year and 100-year, 24-hour storm events for each discharge point.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Total suspended solids removal computations to show compliance.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Design computations for the runoff volume of the pre-developed and post-developed conditions to show compliance with the infiltration requirements.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Design computations for all storm water drainage facilities such as, but not limited to, inflow/outflow rates, hydrographs, water surface elevations, outlet design computations, runoff discharge volume, velocities, and stage/storage data.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Design computations for the 10-year Rational Method flows for all proposed storm conveyance systems.
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Computation of the available downstream capacity flowing full, overflow level of ditches and the top of the upstream end of the pipe for any culverts.
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Computation of the downstream capacity using the 5-year rational storm.
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Tail water analysis included in storm water design for 2-year, 10-year and 100-year storm events.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Design computations to illustrate compliance with pollutant loading criteria (Storm Water Quality Management practices) with pre- and post-storm water management facilities.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Narrative describing all assumptions that were deemed appropriate for design.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Explanation of provisions to preserve and use natural topography and land cover features.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Explanation of restrictions on Storm Water Management practices by wellhead protection plans (if applicable).
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Results of investigations of soil and groundwater required for installation of Storm Water Management practices.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Impact assessment results on Wetland Functional Values (if applicable).
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Storm Water Management practices installation schedule.
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Cost estimate for the construction, operation and maintenance of each Storm Water Management practice.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Any additional information that the City, or designee, may need to evaluate the impacts of the storm water discharge quality and quantity on the existing area and existing utilities.