

# Project Reviews

## City of Waukesha

**Project Number: SPAR21-00027**

Description: **Allied Resource Recovery**

Applied: **6/25/2021**

Approved:

Site Address: **1320 ANOKA AV**

Closed:

Expired:

City, State Zip Code: **WAUKESHA, WI 53186**

Status: **UNDER REVIEW**

Applicant: **Allied Resource Recovery**

Parent Project:

Owner: **Allied Resource Recovery**

Contractor: **<NONE>**

Details:

**PC21-0061**

### LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: ALL						
6/30/2021		7/12/2021	Erosion Control	VELVET WEIER		
Notes:						
6/30/2021	7/13/2021	7/12/2021	Sanitary Sewer	Chris Langemak	REVIEW COMPLETE	See comments
Notes:						
1. Sewer lateral video. The existing building has a sanitary sewer lateral connecting the City's sewer main. Please provide a sewer lateral video to City for review and approval. Contact the City Engineering Department for the video format. If lateral maintenance is needed, then the lateral improvements may need to be included as part of this project. The lateral pipe and connection to the main may need to be lined or relayed to reduce infiltration into the City's sanitary sewer system or improve the structural integrity.						
6/30/2021	7/13/2021	7/12/2021	Storm Sewer	Chris Langemak	REVIEW COMPLETE	No comments
Notes:						
6/30/2021	7/8/2021	7/12/2021	Stormwater	KRISTIAN NYSOME	REVIEW COMPLETE	See notes
Notes:						
The City of Waukesha acknowledges that the proposed project does not meet the applicability criteria for Chapter 32 Storm Water Management.						
6/30/2021	7/2/2021	7/12/2021	Street Lighting	JEFF HERNKE	REVIEW COMPLETE	See notes
Notes:						
No comments regarding City owned street lights and fiber.						

# Project Reviews

## City of Waukesha

6/30/2021	7/9/2021	7/12/2021	Traffic	Michael Grulke	REVIEW COMPLETE	No Comments
Notes:						
6/30/2021		7/12/2021	Wastewater Quality	TIM YOUNG		
Notes:						
Review Group: AUTO						
6/25/2021		7/12/2021	Fire	Brian Charlesworth		
Notes:						
6/25/2021	7/7/2021	7/12/2021	General Engineering	DAVID BUECHL	ADDITIONAL INFO REQUIRED	see notes
Notes:						
1. Provide letter of credits, as applicable.						
6/25/2021		7/12/2021	Planning	ROBIN GRAMS		
Notes:						
6/25/2021	7/6/2021	7/12/2021	Water Utility	Chris Walters	APPROVED	No comments
Notes:						