

# Project Reviews

## City of Waukesha

**Project Number: SPAR22-00014**

Description: **Minor Site Plan - 443 Merrill Hills Rd**

Applied: **4/29/2022**

Approved:

Site Address: **443 MERRILL HILLS RD**

Closed:

Expired:

City, State Zip Code: **WAUKESHA, WI 53188**

Status: **RECEIVED**

Applicant: **GOOD TIMES SUMMER DAY CAMP**

Parent Project:

Owner: **<NONE>**

Contractor: **<NONE>**

Details:

**PC22-0243**

### LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: ALL						
5/4/2022	5/18/2022	5/9/2022	Sanitary Sewer	Chris Langemak	UNDER REVIEW	No comments
Notes:						
Review Group: AUTO						
4/29/2022	5/13/2022	5/19/2022	Building Inspection	KRISTIN STONE	REVIEW COMPLETE	
Notes:						
4/29/2022	5/9/2022	5/9/2022	Fire	Brian Charlesworth	REVIEW COMPLETE	See Notes
Notes:						
The proposed project will require an automatic fire sprinkler system to be added to the entire building. This is required per Municipal ordinance 21.07						
4/29/2022	5/17/2022	5/9/2022	General Engineering	DAVID BUECHL	ADDITIONAL INFO REQUIRED	see notes
Notes:						
1. Pay impact fees. \$124.18 police + \$9,814.90 sewer = Total \$9,939.08						
2. Provide financial guarantee (ie. letter of credit) for landscaping, if landscaping plan required by Plan Commission.						
4/29/2022	5/18/2022	5/9/2022	Planning	Unassigned	REVIEW COMPLETE	
Notes:						