

Project Reviews

City of Waukesha

Project Number: SPAR19-00057

Description: **Fischer Center**

Applied: **11/26/2019**

Approved:

Site Address: **223 MAPLE AV**

Closed:

Expired:

City, State Zip Code: **WAUKESHA, WI 53186**

Status: **UNDER REVIEW**

Applicant: **BFR Services**

Parent Project:

Owner: **ALDONA FISCHER MARITAL TRUST**

Contractor: **<NONE>**

Details:

PC19-0139

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: ALL						
12/2/2019		12/10/2019	Erosion Control	VELVET WEIER		
Notes:						
12/2/2019	12/4/2019	12/10/2019	Sanitary Sewer	Chris Langemak	REVIEW COMPLETE	No comments
Notes:						
12/2/2019	12/11/2019	12/10/2019	Storm Sewer	THOMAS MILES	REVIEW COMPLETE	No comments.
Notes:						
12/2/2019	12/11/2019	12/10/2019	Stormwater	THOMAS MILES	REVIEW COMPLETE	No comments.
Notes:						
12/2/2019	12/4/2019	12/10/2019	Street Lighting	JEFF HERNKE	REVIEW COMPLETE	See notes
Notes: No comments regarding City owned street lighting or fiber.						
12/2/2019	12/23/2019	12/10/2019	Traffic	Michael Grulke	REVIEW COMPLETE	See Comments
Notes: Refer to comments about vehicular access under General Engineering review by Dave Buechl. Care should be taken to limit access of vehicles and pedestrians out of the property and into the unprotected are of the rail road tracks.						

Project Reviews

City of Waukesha

Review Group: AUTO						
11/26/2019	12/11/2019	12/10/2019	Building Inspection	KRISTIN STONE		
Notes:						
11/26/2019		12/10/2019	Fire	Brian Charlesworth		
Notes:						
11/26/2019	12/9/2019	12/10/2019	General Engineering	DAVID BUECHL	ADDITIONAL INFO REQUIRED	see notes
Notes: 1. No vehicle traffic should enter or exit out to Grand Avenue. The proposed fence location will leave a gap of approximately 20 feet along the east lot line/railroad right of way line unless the fence is extend southerly to fence in this lot area.						
11/26/2019		12/10/2019	Parks	Unassigned		
Notes:						
11/26/2019		12/10/2019	Planning	Unassigned		
Notes:						
11/26/2019		12/10/2019	Planning Commission	Doug Koehler		
Notes:						
11/26/2019	1/9/2020	12/10/2019	Water Utility	Chris Walters	REVIEW COMPLETE	No comments
Notes:						