## Project Reviews City of Waukesha

Project Number: CSM22-00017 Description: 2301 Bluemound Rd (former restaurant)

Applied: 12/19/2022 Approved: Site Address:

Closed: Expired: City, State Zip Code: ,

Status: **RECEIVED** Applicant: **Briohn Building Corp** 

Parent Project: Owner: **Dominic J & Elavne M Albanese Living Trust** 

Contractor: <NONE>

Details:

Error on Check #.
Correct CK #11837

PC22-0343

LIST OF REVIEWS									
SENT DATE	RETURNED DATE	DUE DATE	ТҮРЕ	CONTACT	STATUS	REMARKS			
Review Group: ALL									
12/20/2022		1/6/2023	Sanitary Sewer	Chris Langemak					
Notes:									
12/20/2022	1/5/2023	1/6/2023	Storm Sewer	Jonathan Schapekahm	REVIEW COMPLETE	No comments			
Notes:									
12/20/2022		1/6/2023	Street Design	Brandon Schwenn					
Notes:									
12/20/2022	1/3/2023	1/6/2023	Street Lighting	JEFF HERNKE	REVIEW COMPLETE	see notes			
Notes:									
No comments regarding city owned streetlights or fiber.									
12/20/2022	1/5/2023	1/6/2023	Traffic	DERRIN WOLFORD	REVIEW COMPLETE	No comments			
Notes:									
1/12/2023		1/16/2023	General Engineering	David Buechl					
Notes:									



## **Project Reviews City of Waukesha**

Review Group: AUTO										
12/19/2022	12/22/2022	1/6/2023	CSM OR PLAT REVIEW AND CLOSURE	Megan Roessler		see notes				
Notes:  Meets all requirements of review checklist and survey closure guidelines										
12/19/2022		1/6/2023	Common Council	Unassigned						
Notes:										
12/19/2022		1/6/2023	Fire	Brian Charlesworth						
Notes:										
12/19/2022	1/5/2023	1/6/2023	General Engineering	DAVID BUECHL	ADDITIONAL INFO REQUIRED	see notes				
1. Additional required submittals, fees, financial guaranties needed prior to issuance of building permit include: a. Final Site Plan and storm water management plan b. Financial Guarantees c. City Storm Water Permit 2. The storm water management plan, construction drawings, storm water facility maintenance agreement, easements, and financial guarantees should be reviewed and approved prior to the CSM being approved by the City. If the location of any site work needs to be changed as a result of the approved construction drawings, the CSM should be updated to reflect the needed changes. 3.4. In accordance with Wisconsin Administrative Code A-E 2.02(4): Each sheet of plans, drawings, documents, specifications and reports for architectural, landscape architectural, professional engineering, design or land surveying practice should be signed, sealed, and dated by the registrant or permit holder who prepared, or directed and controlled preparation of, the written material. 4.Add note: A separately recorded storm water maintenance agreement describing the rights, conditions, and restrictions of the storm water facilities is recorded at the Waukesha County Register of Deeds. 5. 22.53 Traffic, Loading, Parking and Access (1) TRAFFIC VISIBILITY. (Am. #38-02) In all districts no structures, fences, or vegetation shall be permitted on a corner lot within twenty (20) feet of the point of intersection of the right-of-way lines (the "corner") which obstructs or interferes with traffic visibility.  Show vision corner easement on CSM. Add note to CSM: Vision corner easements: No structure, driveway or improvement of any kind is permitted within the vision triangle. No vegetation, bushes, trees, or other visual obstructions may exceed 24 inches in height within vision corner easements platted hereon. Said vision corner easement is granted to the City of Waukesha. No direct vehicular access is allowed over any vision corner easements. 6. Per Wisconsin State Statute 236.20(2)(f) as referenced by 236.34(1m)(c): Show existing and										
12/19/2022		1/6/2023	Planning	Unassigned						
Notes:										
12/19/2022		1/6/2023	Planning Commission	Unassigned						
Notes:										
12/19/2022		1/6/2023	Water Utility	Chris Walters						
Notes:										

