Project Reviews City of Waukesha

Project Number: SPAR19-00055 Description: Sunburn Enterprises, Corporate Drive

Applied: 11/13/2019 Approved: Site Address:

Closed: Expired: City, State Zip Code: ,

Status: UNDER REVIEW Applicant: DESIGN 2 CONSTRUCT

Parent Project: Owner: Sunburn Enterprises

Contractor: <NONE>

Details:

PC19-0128

LIST OF REVIEWS								
SENT DATE	RETURNED DATE	DUE DATE	ТҮРЕ	CONTACT	STATUS	REMARKS		
Review Group: ALL								
11/21/2019		12/5/2019	Addressing	Bradley Blumer				
Notes:								
11/21/2019		12/5/2019	Erosion Control	VELVET WEIER				
Notes:								
11/21/2019	12/4/2019	12/5/2019	Sanitary Sewer	Chris Langemak	REVIEW COMPLETE	See comments		

Notes:

- 1. Sewer lateral video. The proposed building has a proposed sanitary sewer lateral connecting the City's existing sewer main. Please provide a sewer lateral video to City for review and approval. Contact the City Engineering Department for the video format. If lateral maintenance is needed, then the lateral improvements may need to be included as part of this project. The lateral pipe and connection to the main may need to be lined or relayed to reduce infiltration into the City's sanitary sewer system or improve the structural integrity.
- 2. See requirements for connecting a new lateral to an existing sanitary sewer
- 3. The unused lateral in Venture Ct shall be abandoned at the main.
- 4. A record drawing of the sanitary/storm sewer facilities sealed by a professional engineer or registered land surveyor shall be submitted to the Engineering Division.

11/21/2019		12/5/2019	Storm Sewer	THOMAS MILES	
Notes:					
	T				
11/21/2019		12/5/2019	Stormwater	THOMAS MILES	

Notes:

Project Reviews City of Waukesha

11/21/2019	11/26/2019	12/5/2019	Street Lighting	JEFF HERNKE	REVIEW COMPLETE	See notes		
			long this property. this cor mits of this project. Any q					
11/21/2019		12/5/2019	Traffic	Michael Grulke				
Notes:								
Review Group: AU1	го							
11/13/2019		11/27/2019	Building Inspection	KRISTIN STONE				
Notes:								
11/13/2019		11/27/2019	Fire	Brian Charlesworth				
Notes:								
11/13/2019	11/26/2019	11/27/2019	General Engineering	DAVID BUECHL	ADDITIONAL INFO REQUIRED	see notes		
Notes: 1. Depending on the final design, the following permits or approvals may be needed: a. City of Waukesha Storm Water Erosion Control Permit b. Wisconsin DNR NOI, and NOI for fill site. c. City of Waukesha – Engineering Division Construction Permit 2. Additional required submittals include: a. Easements, if applicable b. Applicable sewer connection charges per Chapter 29.11(c) will be owed to the City for this project. c. Letter of credits 3. The construction drawings, and Bonds should be reviewed and approved prior to the construction being started. 4. In accordance with Wisconsin Administrative Code A-E 2.02(4): Each sheet of plans, drawings, documents, specifications and reports for architectural, landscape architectural, professional engineering, design or land surveying practice should be signed, sealed, and dated by the registrant or permit holder who prepared, or directed and controlled preparation of, the written material. 5. Show and label building side yard setback. 6. Label 20' x 20' vision corner easement on drawings. 7. Label ADA access route from ADA parking spot to building . 8. Provide thicker concrete section across driveways for commercial and industrial uses being 7 or 8 inches.								
11/13/2019		11/27/2019	Parks	Unassigned				
Notes:								
11/13/2019		11/27/2019	Planning	ROBIN GRAMS				
Notes:								



Project Reviews City of Waukesha

11/13/2019		11/27/2019	Planning Commission	Unassigned			
Notes:							
11/13/2019		11/27/2019	Water Utility	Chris Walters			
Notes:							

