

City of Waukesha  
 Department of Public Works  
 130 Delafield Street  
 Waukesha, WI 53188  
 Waukesha-wi.gov

# Sewer Plan Review Checklist

Attachment H  
 (Rev 12/18)

Project Name: HARVEST SOURCE

Engineering & Design Firm: SITE ENGINEERING SERVICES, LLC

## Sanitary System

YES	NO	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Minimum 4" sanitary sewer lateral from the main to the property line, PVC SDR 26 or 35 conforming to ASTM standards D 3034 with rubber gasket joints
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sanitary sewer laterals shall have a green #12 locator wire installed along the entire length. Locator wire shall be brought to the surface at the edge of the building and enclosed in a curb box with "sewer" on the cover.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sampling manhole required for all food service developments (or developments with the potential to become food service) and industrial/manufacturing facilities.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Industrial facilities must complete an industrial discharge form.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Outside drop manhole connection required where drop is greater than 24 inches.
Sanitary Plan View			
YES	NO	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Ghost existing utilities and lateral locations in screened format. Label the pipe size of existing utilities.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Label the proposed sewer and laterals with length, size, and material type
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Material and size of the existing sanitary sewer being connected to.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Label the stub-outs with length, size, slope, and invert elevations (if not profiled).
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Dimensions showing offset from right-of-way to the sewer and separation distance between other utilities.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Show type and size of encasement where needed
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Show flow directions of all proposed mains.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Length of each sewer lateral and height of any lateral risers. Label proposed invert elevations at right-of-way lines.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Distance from downstream manhole to each upstream sewer lateral.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Proposed manholes and cleanouts labeled with a design plan number. Existing manholes labeled with numbers obtained from City records.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Rim and invert elevations at each manhole, based on City of Waukesha datum (for private sewer if not profiled)
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Show and label all easements
Sanitary Profile View			
YES	NO	N/A	
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Stationing.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Existing and proposed surface profiles and elevations over the sewer.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	All utility crossings. Label elevations if known.

<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Pipe material / class, size, length, and percent grade to two (2) decimal places.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Material and size of the existing sanitary sewer being connected to.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Length, type, and size of encasement as needed.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Proposed manholes. Indicate type and diameter.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Label station, rim, and invert elevations, based on City of Waukesha datum, and design plan number for each manhole and cleanout. Existing manholes to be labeled with numbers obtained from City records.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Limits of gravel and/or slurry backfill.
<b>Sanitary for Subdivisions/Large Developments</b>			
<i>(Complete copies of City specifications for sanitary sewer are available upon request.)</i>			
<b>YES</b>	<b>NO</b>	<b>N/A</b>	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Each parcel should have a separate sanitary sewer lateral.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Sanitary sewer – 8 ft. horizontal separation from water main per DNR requirements. 8" diameter minimum size, PVC SDR 26 for depths up to 25 ft.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Sanitary sewer manhole at every change of direction and a maximum distance of 400 ft.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	A chimney seal shall be required on all manholes.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Provide copies of all approved WDNR/WDOC submittals, including sewer sizing calculation worksheet and the area served.

### Storm System

<b>Storm Plan View</b>			
<b>YES</b>	<b>NO</b>	<b>N/A</b>	
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Ghost existing utilities and lateral locations in screened format. Pipe size of existing utilities labeled.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Proposed sewer and laterals with length, size, and material type clearly labeled.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Material and size of the existing storm sewer being connected to.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Stub-outs labeled with length, size, slope, and invert elevations (if not profiled).
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Dimensions showing offset from right-of-way to the sewer and separation distance between other utilities.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Type and size of encasement where needed
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Length of any sewer lateral. Label proposed invert elevations at right-of-way lines.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Proposed inlets, manholes, and other drainage structures.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Proposed drainage structures labeled with a design plan number. Existing drainage structures labeled with numbers obtained from City records.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Details of outfall or ditch inlet protection requirements such as rip-rap, end sections or headwalls as needed.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Details of detention facilities, outfall, overflow and control structures as needed.
<b>Storm Profile View</b>			
<b>YES</b>	<b>NO</b>	<b>N/A</b>	
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Stationing.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Existing and proposed surface profiles and elevations over the sewer.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	All utility crossings. Label elevations if known.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Pipe material / class, size, length, and percent grade to two (2) decimal places.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Material and size of the existing storm sewer being connected to
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Length, type, and size of encasement as needed.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Proposed inlets, manholes, and other drainage structures. Label type and size.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Label station, rim, and invert elevations, based on City of Waukesha datum, at each manhole, catch basin, inlet, and detention control structure.

<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Proposed drainage structures labeled with a design plan number. Existing drainage structures to be labeled with numbers obtained from City records.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Cross-section of open channels and detention facilities, including outfall, overflow, and control structures.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Limits of gravel and/or slurry backfill.

### **General System**

YES	NO	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Show all easements, public or private.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	No structures allowed within a public easement.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Plantings or signs within public easements, if permitted by City, shall be at least 5 feet from the utilities.

#### **General for Subdivisions/Large Developments**

YES	NO	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Provide plans sealed by Registered Professional Engineer
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Show benchmark, north arrow and scale.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Show existing/proposed sewer and water utilities.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	All sewer to be installed by the developer under the terms of a Development Agreement.

#### **Utility Plans**


YES	NO	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Location of all utilities: storm and sanitary sewers, water mains, fire hydrants, electrical, natural gas, and communication (cable television, telephone, etc.) lines
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Exterior lighting for parking and other outdoor areas, outdoor signs, and building exteriors.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Location of waste and trash collection, and indicate plans for snow removal.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Location and footprint of any and all buildings
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Location and names of existing and proposed streets
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Location and size of existing and proposed storm sewer, sanitary sewer, and water utility systems shown
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Electric, gas, telephone, and cable lines shown
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	All new utilities are underground
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Exterior lighting detail provided
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Location of all utility and private fire hydrants
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sampling manhole shown (if applicable)
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Grease interceptor shown (if applicable)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Location and size of existing and proposed water meters

#### **Include the following notes on the Utility Plan:**

YES	NO	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	All sanitary sewer to be installed in accordance with City of Waukesha standards.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	All applications and fees for sanitary sewer must be completed and paid prior to connection to sewer systems.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Any utility work in the right-of-way and all sanitary sewer connections to be inspected by City. Notify City 72 hours in advance of connecting to sewer.

*The above list contains items that are commonly missed on Utility Plans. For subdivisions or other large or complex projects, a complete plan review includes many more checks too numerous to list here. Please call (262) 524-3600 for additional information. City typical sewer details can be provided upon request.*

**Note:** For water main, contact Waukesha Water Utility at (262) 521-5272



City of Waukesha  
 Department of Public Works  
 130 Delafield Street  
 Waukesha, WI 53188  
 Waukesha-wi.gov

## Site, Grading and Drainage Plan Conditional Use Permit Checklist

Attachment C  
 (Rev 12/18)

Project Name: HARVEST SQUARE

Engineering & Design Firm: SITE ENGINEERING SERVICES, LLC

### General Requirements

YES	NO	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Applicant's name
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Name and location of development
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Scale and north arrow
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Date of original and revisions noted
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	License number and professional seal
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Digital Drawings in AutoCAD format of the site layout & building plan layout
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Pay impact fees

### Building Plans

YES	NO	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Contact Community Development Department

### Site Plans

YES	NO	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Dimensions of development site
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Location, footprint, and outside dimensions
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Existing and proposed pedestrian access points
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Existing and proposed vehicular access points
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Parking lots, driveways shown
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Front, side and rear yard setbacks shown and labeled
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Location, identification and dimensions of all existing or planned easements
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Identification of all land to be dedicated
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Location, elevation, and dimensions of walls and fences
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Location of outdoor lighting with lighting design plan and calculations
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sign complies with City Code Book
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Location of existing and proposed signs

### Site Access

YES	NO	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Legal description or certified survey of property
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Development compatible with its zoning district
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sidewalks to be shown
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Site entrance drive dimensions
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Individual development vehicular entrances at least 125 feet apart
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Adjacent development share driveway where possible
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	At least one vehicular and pedestrian access point to each adjoining site granted by cross easements
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Cross access to be provided with minimum paved width of 24 feet
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Design detail for all new public streets

### Parking/Traffic

YES	NO	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5-foot wide (min) paved walkway to building entrance
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	7-foot parking separation from front of building
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Minimum parking spaces provided
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Service truck parking in designated service areas
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Parking spaces and layout dimensioned
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Lot paved with HMA or concrete
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Handicap parking provided
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Minimum required stacking distance
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Concrete curb and gutter around parking lot

### Grading and Drainage Plans

YES	NO	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Show existing tree lines and any obstructions (fences, structures, power poles, etc.) within the project limits.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	All proposed lot lines and lot numbers or addresses
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Lot line dimensions
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Outline of buildable areas for each lot
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Typical setbacks of buildable area to front, side and back lot lines
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	All existing buildings, structures and foundations
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	All existing drainage channels and watercourses
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Emergency overflow routes
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Drainage clarified by flow arrows, high points, sags, ridges, and valley gutters
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Proposed retaining wall locations with top and bottom of wall elevations at key locations <i>BUILDING FOUNDATION WALL IS RETAINING WALL</i>
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	100-year flood plain limit (both pre-and post-project)
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	100-year storm water surface elevation
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Wetlands. Wetland limits labeled with bearings and distances and dimensioned to lot lines. Bearings and distances may be shown in tabulated format.

<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	All environmental corridors, & or environmentally sensitive areas as required by DNR
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	All existing and proposed easements.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Existing topography of the site and all areas within 50 feet of the site shown at a one foot contour interval using City of Waukesha datum. Existing contours shown as thin, dashed screened or grey lines with a readily discernable heavier line used for the 5-foot contour intervals.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Proposed grading shown at a contour interval of 1 foot using City of Waukesha datum. Proposed contour lines shown as solid medium lines, with a discernible heavier line use for the 5-foot contour intervals.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	The yard grade and first floor elevation of proposed building and any existing buildings located within 150 feet of the parcel boundary.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Proposed road(s), curb and gutter, all storm sewer grates and storm sewer manholes (or cross-culverts for open ditches). Show any off-road storm inlets and discharge locations with surface entry elevations.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Spot grades as necessary to ensure proper drainage and compliant ADA slopes and routing where applicable.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	At front setback line show a typical house shell on each lot and the proposed yard grade to the nearest tenth of a foot (assumed to be 0.7' below the top of block) for each building. Show proposed finished elevations to the nearest tenth of a foot at all lot corners and alongside lot lines adjacent to the front and back corners of the typical house. Show proposed finished elevations to the nearest tenth of a foot at high and low points along any side or back lot lines, and at high and low points if roads to demonstrate proposed drainage.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	The grading plan for any house that will require special design due to topography, clearly show separate grades for the garage and yard grade if extra steps are needed. Separate spot finish elevations shown for rear or side exposure or walkout.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Indicate minimum finished floor elevations adjacent to floodplains, ponds, creeks/channels, etc.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Proposed storm inlets shown on each grading plan. Each plan also includes specific details on all applicable retention/detention basins, ponds, overflows, etc. Separate sheets or notes as required.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Locations of existing and proposed streets, drives, alleys, easements, right-of-way, parking as required, vehicular and pedestrian access points, and sidewalks
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Outline of any development stages
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Location and details on any required emergency access roads
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Soil characteristics
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Existing and proposed topography shown for the site and or adjacent properties
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Floodplain, shore land, environmental and wetlands shown
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Location and dimensions of on-site storm water drainage facilities
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Location and footprint of all existing buildings
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Locations and species of existing trees
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Berm detail
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Lot grades and swales shown
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Drainage calculations provided

## Erosion Control

YES	NO	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Location Map
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Soils Survey Map
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Existing Land Use Mapping
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Predeveloped Site Conditions
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	• Existing contours
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	• Property lines
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	• Existing flow paths and direction
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	• Outlet locations
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	• Drainage basin divides and subdivides
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	• Existing drainage structures on and adjacent to the site
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	• Nearby watercourses
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	• Lakes, streams, wetlands, channels, ditches, etc.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	• Limits of the 100-year floodplain
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Practice location/layout/cross sections
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Construction Details
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Name of receiving waters
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Site description/Nature of construction activity
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sequence of construction
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Estimate of site area and disturbance area
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pre- and post-developed runoff coefficients <i>SEE STORMWATER REPORT</i>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Description of proposed controls, including
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	• Interim and permanent stabilization practices
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	• Practices to divert flow from exposed soils
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	• Practices to store flows or trap sediment
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	• Any other practices proposed to meet ordinance
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Existing topography of the site and all areas within 50 feet of the site shown at a one foot contour interval using City of Waukesha datum. Existing contours shown as thin, dashed screened or grey lines with a readily discernable heavier line used for the 5-foot contour intervals.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Proposed grading shown at a contour interval of 1 foot using City of Waukesha datum. Proposed contour lines shown as solid medium lines, with a discernible heavier line use for the 5-foot contour intervals.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	List the total disturbed acreage including offsite areas.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Provide <u>free</u> survey in accordance with City Erosion Control Ordinance
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Proposed limits of disturbance including proposed tree cutting areas.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Location and dimensions of all temporary topsoil and dirt stockpiles.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Location and dimensions of all appropriate best management practices (BMP).
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Phasing of BMP's with the construction activities listed / described.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Schedule of anticipated starting and completion date of each land disturbing and land developing activity, including the installation of the BMP measures that are needed.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Location of all channels, pipes, basins or other conveyances proposed to carry runoff to the nearest adequate outlet, including applicable design assumptions and computations.

<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Areas to be sodded or seeded and mulched or otherwise stabilized with vegetation, describing the type of final vegetative cover.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Areas of permanent erosion control (other than vegetation).
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Boundaries of the construction site
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Drainage patterns/slopes after grading activities
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Areas of land disturbance
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Locations of structural and nonstructural controls
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Drainage basin delineations and outfall locations

**Optional Submittals as Determined by Review Authority**


YES	NO	N/A	
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Traffic impact analysis
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Environmental impact statement
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Soil and Site Evaluation Report per DNR Technical Standard 1002
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Plot of effect of exterior illumination on site and adjacent properties
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Description of any unusual characteristics
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Street perspectives showing view corridors
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Historic site
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Economic feasibility study
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Contaminated Waste Site

I hereby certify that I have reviewed the City ordinances and provided one (1) full-sized set of all required information along with all the required reduced copies of plans.

**Applicant's Signature:**

*Jim Wall*, MANAGER





City of Waukesha  
 Department of Public Works  
 130 Delafield Street  
 Waukesha, WI 53188  
 Waukesha-wi.gov

## Engineering Plan Checklist

Attachment B  
 (Rev 12/18)

Project Name: HARVEST SQUARE

Engineering & Design Firm: SPE ENGINEERING SERVICES, LLC

### General Information

Plans shall include the seal and signature of the Wisconsin licensed professional engineer responsible for the preparation of the construction plans on the cover sheet or on each sheet

YES	NO	N/A	
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Provide a copy of the WisDOT permit for any work in the State of Wisconsin right of way.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Provide a copy of the Waukesha County Department of Public Works permit for any work in right of way of Waukesha County.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Provide a copy of Wisconsin Department of Natural Resources Water Resources Application for Project Permits (WRAPP) for all sites greater than one acre.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Provide a copy of US Army Corps of Engineers 404 permit.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Provide cross access agreements for use of entrances. CSM
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Provide off-site utility easements. CSM
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Provide hydraulic gradeline calculations for all storm sewer pipes signed and sealed by a professional engineer licensed in the State of Wisconsin.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Provide a storm water management plan and calculations signed and sealed by a professional engineer licensed in the State of Wisconsin. REPORT FOR GOOD HARVEST

### All Plan Sheets

YES	NO	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Plans prepared on sheets measuring 11" high by 17" wide or no larger than 24" high by 36" wide.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Sanitary Sewer, watermain and storm sewer system plans for the entire development are included.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	A profile view is located below a plan view on plan and profile sheets and both views are aligned by stationing whenever possible. In general, stationing is from left to right.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Plan and profile sheets start and terminate at match lines.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	The assumed bearing base, control monuments and stationing reference line(s)
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Right-of-way limits and easement limits
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Edge of pavement or flange, face and back of curb
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Name of each existing, proposed, and future roadway and any intersecting roadways
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Lot lines, lot and block numbers
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Addresses and names of Owners for existing parcels

<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	All obstructions located within the project limits including, but not limited to: trees, signs, utilities, fences, light poles, structures, etc.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	A note warning that underground utilities must be located by "Diggers Hotline" prior to start of construction
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Legend (relevant to each sheet) showing all special symbols, line types and hatch used
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Title block includes at a minimum, the following information: Name and address of engineering (design) firm and owner/developer Date of the drawing and last revision Scale Plan sheet number (# of #) Name and location description of development
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	North to the top or right of the sheet and shown by a north arrow, clearly shown without intrusion.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Scale of the plans 1" = 40' horizontally and 1" = 8' vertically for 11" by 17" plan sheets and 1" = 20' horizontally and 1" = 4' vertically for 22" by 34" sheets. Partial site plans have a scale of 1" = 20' or larger. The scale of details is such that the detail is clearly shown. The scale is shown with a line scale and text.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Existing surface objects indicated with screened lines and clearly labeled.

### Cover Sheet

YES	NO	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Project title.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Location Map (Proximity to two main streets minimum).
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Index of all plan sheets
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	For large or phased subdivisions, a key map of layout and phases.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	A minimum of two (2) current SEWRPC reference benchmarks. Survey documentation of tie to Wisconsin State Plane Coordinate System, South Zone (horizontal) and City of Waukesha datum (vertical) provided. Elevations shown based on City of Waukesha datum.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	All permanent or temporary benchmarks and elevations.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	A description of the locations of the benchmarks; and the basis or origin of the vertical control network.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Date of plan preparation and applicable revision date(s)
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	The following statement: " <i>All site improvements and construction shown on the plans shall conform to the City of Waukesha <u>Development Handbook &amp; Infrastructure Specifications</u>. Where the plans do not comply, it shall be the sole responsibility and expense of the Developer to make revisions to the plans and/or constructed infrastructure to comply.</i> "

## Roadway

YES	NO	N/A	
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	For all new streets, a site specific geotechnical evaluation and pavement design submitted with the plans.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	A separate detail sheet showing typical cross-sections for each roadway standard width and cul-de-sac if applicable.

## Plan View

YES	NO	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	The assumed bearing base, control monuments and stationing reference line along the centerline of the roadway, including cul-de-sacs.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	At least one clearly labeled benchmark or control point per sheet.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pavement and median dimensions.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Final grade elevations at 25' intervals at the right-of-way including at the edge of pavement for rural sections or at the flange of curb for urban sections.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Final grade elevations for cul-de-sacs at 25' intervals at the right-of-way including at the edge of pavement for rural sections or at the flange of curb for urban sections.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Label all PVC's, PVT's, and PC's, PT's for vertical and horizontal curves. Radii of all intersections (edge of pavement or flange of curb, with note indicating which is referenced).
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Driveways for all lots adjacent to storm inlets and intersections.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Sidewalks labeled and dimensioned.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Existing, proposed, future streets and drives labeled and dimensioned.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	All roadside ditch locations, flowline elevations at 50' intervals of the ditches.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Slope intercepts.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Invert profile for 200' downstream for any existing ditches receiving flow from a proposed road or street.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Limits of any areas which need special stabilization techniques.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Specific details of all existing connected roadways. Pavement, shoulders, ditches, curb alignment, and grades shall be shown as needed to adequately make the transition.

## Intersection Details

YES	NO	N/A	
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Radii of all intersections (edge of pavement or flange of curb, with note indicating which is referenced).
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Sidewalks and accessible ramps labeled and dimensioned.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Right of way corner clips and sight visibility easements.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Spot grades as necessary to ensure proper drainage and compliant ADA slopes.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Spot grades shall be shown at end of radius for all curb and gutter and the end radius for all back of sidewalk.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Drainage clarified by flow arrows, high points, sags, ridges, etc. Slope intercepts shall be clearly labeled by station, elevation to the nearest 0.1', and offset distance (left or right) from the reference line.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Invert elevation of ditches (for rural roadway).
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Final subgrade elevation at the centerline of the street or roadway.

## Cross Sections

YES	NO	N/A	
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Right of way limits.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Slope intercepts clearly labeled.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Elevations to the nearest 0.01'.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Offset distance (left or right) from the reference line.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Final grade elevations at back of walk, face of walk, top of curb, flange elevation (edge of pavement for rural section), and the centerline of the street or roadway.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Cross slope of sidewalk, terrace area, and roadway.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Invert elevation of ditches (for rural section)