

Project Reviews

City of Waukesha

Project Number: CNSLT20-00002

Description: **PC Consultation**

Applied: **4/7/2020**

Approved:

Site Address: **200 DELAFIELD ST**

Closed:

Expired:

City, State Zip Code: **WAUKESHA, WI 53188**

Status: **RECEIVED**

Applicant: **<NONE>**

Parent Project:

Owner: **CITY OF WAUKESHA**

Contractor: **<NONE>**

Details:

ID#20-0459

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: ALL						
4/7/2020		4/21/2020	Fire	Brian Charlesworth		
Notes:						
4/7/2020		4/21/2020	General Engineering	David Buechl		
Notes:						
4/7/2020		4/21/2020	Planning	Doug Koehler		
Notes:						
4/7/2020		4/21/2020	Water Utility	Chris Walters		
Notes:						
4/7/2020	4/16/2020	4/21/2020	Traffic	Michael Grulke	REVIEW COMPLETE	See Comments
Notes: See comments from subsequent review from 4/16/20						
4/8/2020		4/21/2020	Sanitary Sewer	Chris Langemak		
Notes:						
4/8/2020		4/21/2020	Storm Sewer	Chris Langemak		
Notes:						

Project Reviews

City of Waukesha

4/8/2020		4/21/2020	Street Lighting	Jeff Hernke		
----------	--	-----------	-----------------	-------------	--	--

Notes:

4/8/2020	4/16/2020	4/21/2020	Traffic	Michael Grulke	REVIEW COMPLETE	See Comments
----------	-----------	-----------	---------	----------------	-----------------	--------------

Notes:

The driveway to Delafield Street is aligned with Beuna Vista and seems to work out for the site.

Will be old retaining wall be removed? If so, how will the site be graded? The site shows trees and bushes existing along Delafield Street, but if the retaining wall is removed, those bushes / trees may need to be removed and replanted because the wall will be replaced with a slope (?).

No traffic impact study is required for this development.