

Project Reviews

City of Waukesha

Project Number: CU20-00007

Description: **Family Promise of Waukesha County**

Applied: **5/26/2020**

Approved:

Site Address: **139 E NORTH ST**

Closed:

Expired:

City, State Zip Code: **WAUKESHA, WI 53188**

Status: **UNDER REVIEW**

Applicant: **Family Promise of Waukesha County**

Parent Project:

Owner: **KAUPP REALTY LLC**

Contractor: **<NONE>**

Details:

PC20-0047 and PC20-0048

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: ALL						
6/8/2020	6/10/2020	6/8/2020	Sanitary Sewer	Chris Langemak	REVIEW COMPLETE	No comments
Notes:						
6/8/2020	6/8/2020	6/8/2020	Street Lighting	Jeff Hernke	REVIEW COMPLETE	See notes
Notes:						
No comments regarding City owned street lights or fiber.						
6/10/2020	6/10/2020	6/10/2020	Storm Sewer	Chris Langemak	REVIEW COMPLETE	See comments
Notes:						
The building has an existing sump pump that discharges towards the municipal parking lot at the rear of the property. The sump pump discharge causes ice to build up in the parking lot. The discharge shall be redirected elsewhere to avoid icing problems in the parking lot or sidewalks.						
Review Group: AUTO						
5/26/2020	6/15/2020	6/9/2020	Building Inspection	KRISTIN STONE	REVIEW COMPLETE	
Notes:						
Any changes to the building by alterations, additions, change of occupancy classification or use. Will require a Licensed Design Professional. Certificate of occupancy is required.						
5/26/2020	6/8/2020	6/7/2020	General Engineering	DAVID BUECHL	REVIEW COMPLETE	see notes
Notes:						
1. No comments.						

Project Reviews

City of Waukesha

5/26/2020	6/17/2020	6/7/2020	Water Utility	Chris Walters	APPROVED	No comments
Notes:						