

# Project Reviews

## City of Waukesha

**Project Number: SPAR26-00002**

Description: **Final SPAR, 1808 Silvernail Rd, UW Credit Union**

Applied: **1/27/2026**

Approved:

Site Address: **1808 SILVERNAIL RD**

Closed:

Expired:

City, State Zip Code: **PEWAUKEE, WI 53072**

Status: **RECEIVED**

Applicant: **KEE Architecture Inc.**

Parent Project:

Owner: **UW Credit Union, PJ Thieren**

Contractor: **<NONE>**

Details:

**PC26-0005**

### LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: AUTO						
1/27/2026	1/27/2026	2/10/2026	Building Inspection	KRISTIN STONE	REVIEW COMPLETE	No remarks
Notes: Contact State of Wisconsin for tank removal requirements.						
1/27/2026	1/30/2026	2/10/2026	Fire	Brian Charlesworth	REVIEW COMPLETE	None
Notes:						
1/27/2026	2/9/2026	2/10/2026	General Engineering	Josh Meyerhofer	REVIEW COMPLETE	See notes
Notes: MSA review comments included in attachments.						
1/27/2026		2/10/2026	Parks	Melissa Lipska		
Notes:						
1/27/2026	2/17/2026	2/10/2026	Planning	CHARLIE GRIFFITH	REVIEW COMPLETE	
Notes: <ul style="list-style-type: none"> <li>Provide additional evergreen landscaping to screen headlights in the drive through lane from on-coming traffic on Grandview Blvd. Updated landscape plan must be approved by staff prior to issuance of Building Permits.</li> <li>Lighting color temperature may not exceed 4,000k.</li> </ul>						
1/27/2026		2/10/2026	Planning Commission	Unassigned		
Notes:						

# Project Reviews

## City of Waukesha

1/27/2026	1/29/2026	2/10/2026	Water Utility	Mat Kadrich	REVIEW COMPLETE	see notes
-----------	-----------	-----------	---------------	-------------	-----------------	-----------

Notes:

- 1) WWU will need a water lateral application filled out and submitted for meter sizing.
- 2) The existing 1" copper service in the center of the lot will need to be abandoned at the water main by turning the corp off and capping the corp. WWU will need to inspect this.