

# Project Reviews

## City of Waukesha

**Project Number: CU19-00009**

Description: **Hughes Automotive**

Applied: **11/12/2019**

Approved:

Site Address: **1711 ARTHUR CT**

Closed:

Expired:

City, State Zip Code: **WAUKESHA, WI 53188**

Status: **UNDER REVIEW**

Applicant: **Hughes Automotive**

Parent Project:

Owner: **JOHN & TERESE M DAL SANTO**

Contractor: **<NONE>**

Details:

**PC19-0125**

### LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: ALL						
11/12/2019		11/26/2019	Erosion Control	VELVET WEIER		
Notes:						
11/12/2019	12/4/2019	11/26/2019	Sanitary Sewer	Chris Langemak	REVIEW COMPLETE	See comments
Notes:						
1. Sewer lateral video. The existing building has a sanitary sewer lateral connecting the City's sewer main. Please provide a sewer lateral video to City for review and approval. Contact the City Engineering Department for the video format. If lateral maintenance is needed, then the lateral improvements may need to be included as part of this project. The lateral pipe and connection to the main may need to be lined or relayed to reduce infiltration into the City's sanitary sewer system or improve the structural integrity.						
11/12/2019		11/26/2019	Storm Sewer	THOMAS MILES		
Notes:						
11/12/2019		11/26/2019	Stormwater	THOMAS MILES		
Notes:						
11/12/2019	11/15/2019	11/26/2019	Street Lighting	JEFF HERNKE	REVIEW COMPLETE	See notes
Notes:						
No comments regarding City owned street lights or fiber.						
11/12/2019		11/26/2019	Traffic	Michael Grulke		
Notes:						

# Project Reviews

## City of Waukesha

Review Group: AUTO						
11/12/2019		11/26/2019	Fire	Brian Charlesworth		
Notes:						
11/12/2019	11/12/2019	11/26/2019	General Engineering	DAVID BUECHL	ADDITIONAL INFO REQUIRED	see notes
Notes:						
General						
1. Additional required submittals, fees, financial guaranties needed prior to issuance of building permit include:						
a. Letter of credits						
11/12/2019		11/26/2019	Planning	ROBIN GRAMS		
Notes:						
11/12/2019		11/26/2019	Water Utility	Chris Walters		
Notes:						