

# Project Reviews

## City of Waukesha

**Project Number: SPAR23-00052**

Description: **Minor SPAR, 225 Carroll St**

Applied: **11/14/2023**

Approved:

Site Address: **225 CARROLL ST**

Closed:

Expired:

City, State Zip Code: **WAUKESHA, WI 53186**

Status: **RECEIVED**

Applicant: **Buetow Lighting, Ryan Venturelli**

Parent Project:

Owner: **CARROLL UNIVERSITY INC**

Contractor: **<NONE>**

Details:

**PC23-0477**

### LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: ALL						
11/20/2023	11/29/2023	11/28/2023	SANITARY SEWER	Chris Langemak	REVIEW COMPLETE	No comments
Notes:						
11/20/2023	11/21/2023	11/28/2023	STREET LIGHTING	JEFF HERNKE	REVIEW COMPLETE	See notes
Notes:						
No comments regarding city owned streetlights or fiber.						
11/20/2023	11/21/2023	11/28/2023	TRAFFIC	DERRIN WOLFORD	REVIEW COMPLETE	No comments
Notes:						
Review Group: AUTO						
11/14/2023	11/28/2023	12/4/2023	Building Inspection	KRISTIN STONE	REVIEW COMPLETE	
Notes:						
11/14/2023	11/14/2023	11/28/2023	Fire	Brian Charlesworth	REVIEW COMPLETE	None
Notes:						
11/14/2023		11/28/2023	General Engineering	Brandon Schwenn		
Notes:						

# Project Reviews

## City of Waukesha

11/14/2023		11/28/2023	Parks	Melissa Lipska		
Notes:						
11/14/2023	12/1/2023	11/28/2023	Planning	Unassigned	REVIEW COMPLETE	
Notes: Provide a photometric plan extended to the property boundary to verify that light spillover does not exceed 0.5 footcandles.						
11/14/2023		11/28/2023	Planning Commission	Unassigned		
Notes:						
11/14/2023	11/15/2023	11/28/2023	Water Utility	Chris Walters	APPROVED	No comments
Notes:						