

Project Reviews

City of Waukesha

Project Number: CU19-00012

Description: **Precision Diagnostics, Inc.**

Applied: **12/6/2019**

Approved:

Site Address: **1701 PEARL ST**

Closed:

Expired:

City, State Zip Code: **WAUKESHA, WI 53186**

Status: **UNDER REVIEW**

Applicant: **David Zielke**

Parent Project:

Owner: **WAUKESHA EAST COMMERCE**

Contractor: **<NONE>**

Details:

PC19-0141

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: ALL						
12/26/2019	1/15/2020	1/6/2020	Sanitary Sewer	Chris Langemak	REVIEW COMPLETE	See comments
Notes:						
1. Sewer lateral video. The existing building has a sanitary sewer lateral connecting the City's sewer main. Please provide a sewer lateral video to City for review and approval. Contact the City Engineering Department for the video format. If lateral maintenance is needed, then the lateral improvements may need to be included as part of this project. The lateral pipe and connection to the main may need to be lined or relayed to reduce infiltration into the City's sanitary sewer system or improve the structural integrity.						
12/26/2019	1/6/2020	1/6/2020	Street Lighting	JEFF HERNKE	REVIEW COMPLETE	See notes
Notes:						
No comments regarding City owned street lights or fiber.						
Review Group: AUTO						
12/6/2019	1/9/2020	12/20/2019	Building Inspection	KRISTIN STONE	WITHDRAWN	
Notes:						
12/6/2019		12/20/2019	Fire	Brian Charlesworth		
Notes:						
12/6/2019		12/20/2019	Planning	Unassigned		
Notes:						
12/6/2019		12/20/2019	Planning Commission	Unassigned		
Notes:						

Project Reviews

City of Waukesha

12/6/2019	1/9/2020	12/20/2019	Water Utility	Chris Walters	REVIEW COMPLETE	No comments.
Notes:						
12/26/2019	12/26/2019	1/6/2020	General Engineering	DAVID BUECHL	REVIEW COMPLETE	see notes
Notes: 1. No comments						