



COMMUNITY DEVELOPMENT

201 DELAFIELD STREET
WAUKESHA, WISCONSIN 53188-3633
TELEPHONE 262-524-3750

Jennifer Andrews, Director

jandrews@waukesha-wi.gov

NOTICE OF DECISION OF THE CHIEF BUILDING INSPECTOR

February 10, 2022

Please take notice that the permit requested by application for the purpose for:

Constructing a bathroom with ceiling height of less than 5 feet until beyond the back of the water closet. a single-family home located at: **935 N Greenfield Ave, Waukesha, WI**, is hereby denied because the application fails to comply with the code of the City of Waukesha:

Section 16.01 (b). This section adopts the Uniform Dwelling code for all new and existing one- and two-family dwellings. The Uniform Dwelling Code, Chapter **SPS 321.06(3), requires the ceiling height extending back from the front edge of a water closet may slope below 7 feet, but may not go below 5 feet until beyond the back of the water closet.**

An appeal from this decision may be taken to the Board of Building Appeals as provided in the Code of the City of Waukesha. The appeal must be filed in the office of Community Development-Planning Department within twenty (14) days of the date of this notice.

Kristin Stone - Chief Building Inspector/Board of Building Appeals Secretary