

Project Reviews

City of Waukesha

Project Number: SPAR22-00017

Description: **Minor SPAR -CT Replacement & Exterior Trailer Pad**

Applied: **5/25/2022**

Approved:

Site Address: **725 AMERICAN AV**

Closed:

Expired:

City, State Zip Code: **WAUKESHA, WI 53188**

Status: **RECEIVED**

Applicant: **Ron Boecker, Pro Health Care**

Parent Project:

Owner: **PROHEALTH CARE INC**

Contractor: **<NONE>**

Details:

PC22-0255

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: ALL						
6/6/2022	6/8/2022	6/9/2022	Traffic	DERRIN WOLFORD	REVIEW COMPLETE	No comments
Notes:						
6/6/2022	6/8/2022	6/8/2022	Sanitary Sewer	Chris Langemak	REVIEW COMPLETE	No comments
Notes:						
Review Group: AUTO						
5/25/2022	6/14/2022	6/14/2022	Building Inspection	KRISTIN STONE	REVIEW COMPLETE	
Notes:						
5/25/2022	6/7/2022	6/4/2022	Fire	Brian Charlesworth	REVIEW COMPLETE	
Notes:						
5/25/2022	6/6/2022	6/4/2022	General Engineering	DAVID BUECHL	ADDITIONAL INFO REQUIRED	see notes
Notes:						
1. Proposed curb and gutter should be labeled as either accept or reject to correspond with details. Add drainage arrows. The curb and gutter spot grades don't appear to correspond to the legend. Confirm no drainage issues are being created.						
5/25/2022		6/4/2022	Parks	Melissa Lipska		
Notes:						

Project Reviews

City of Waukesha

5/25/2022	6/16/2022	6/4/2022	Planning	Doug Koehler	UNDER REVIEW	see notes
Notes: If landscaping along the building in the area of work, is damaged or removed, it is to be replaced when paving is complete. Landscaping should be used to screen the electrical hook up for the temporary trailer.						
5/25/2022		6/4/2022	Planning Commission	Unassigned		
Notes:						
5/25/2022		6/4/2022	Water Utility	Chris Walters		
Notes:						