



**FIRE DEPARTMENT**

**FIRE PREVENTION BUREAU**

130 W. ST. PAUL AVENUE  
WAUKESHA, WISCONSIN 53188-5172  
TELEPHONE: (262) 524-3648 FAX: (262) 524-3670

**Brian Charlesworth, Fire Marshal**

bcharles@ci.waukesha.wi.us

**CITY OF WAUKESHA FIRE DEPARTMENT  
PROPOSED PROJECTS FOR PLAN COMMISSION  
MEETING OF AUGUST 24, 2016**

- 1) CALL TO ORDER
- 2) PLEDGE OF ALLEGIANCE
- 3) ROLL CALL
- 4) APPROVAL OF MINUTES
  - A. (ID#16-1218) MINUTES FOR THE AUGUST 10, 2016 MEETING
    - No Concerns/Issues Noted
- 5) CONSENT AGENDA
- 6) OPEN PUBLIC HEARING
  - A. (PC16-0070) PUBLIC HEARING – PROJECT PLAN AMENDMENT TID NO. 9
    - No Concerns/Issues Noted
- 7) ACTION ON PUBLIC HEARING
  - A. (ID#16-1280) RESOLUTION: TO APPROVE PROJECT PLAN AMENDMENT TID NO. 9
    - No Concerns/Issues Noted
- 8) BUSINESS ITEMS
  - A. (PC16-0066) CLEARPOINT – MAIN ST. & BARSTOW – PRELIMINARY SITE PLAN & ARCHITECTURAL REVIEW
    - Per City of Waukesha Municipal Ordinance 21.07 and International Fire Code Section 903.2.8, this building will be required to be fully protected by an automatic fire sprinkler system. This building will also be required to have a standpipe system in accordance with Section 905 of the International Fire Code. The building will be required to be equipped with an automatic fire alarm system installed in accordance with Section 907.2.9 of the International Fire Code. The building will also need to meet the requirements for emergency responder radio coverage in accordance with Section 510 of the International Fire Code.
  - B. (PC16-0069) CLEARPOINT – MAIN ST. & BARSTOW – CONDITIONAL USE PERMIT
    - No Concerns/Issues Noted
  - C. (PC16-0068) ORGANIX RECYCLING, LLC – 1100 S. PRAIRIE - CONDITIONAL USE PERMIT
    - No Concerns/Issues Noted