

| TYPE | DESCRIPTION | LAMP TYPE | VOLT | WATTS | MANUFACTURER | CATALOG NUMBER | NOTE |
|------|--|-----------|---------|-------|--------------|----------------------------------|------|
| H2 | SIZE 1 LED WALL PACK - FULL CUTOFF - TYPE 3 MEDIUM - 2774 LUMENS | 5000K LED | 120-277 | 26 | LITHONIA | DSXW1LED-10C-700-50K-T3M-MVOLT | 1 |
| НЗ | SIZE 1 LED WALL PACK - FULL CUTOFF - TYPE 3 MEDIUM - 5487 LUMENS | 5000K LED | 120-277 | 46 | LITHONIA | DSXW1LED-20C-700-50K-T3M-MVOLT | 1 |
| H5 | SIZE 2 LED WALL PACK - FULL CUTOFF - TYPE 3 MEDIUM - 6507 LUMENS | 5000K LED | 120-277 | 54 | LITHONIA | DSXW2LED-30C-530-50K-T3M-MVOLT | 1 |
| H6 | SIZE 2 LED WALL PACK - FULL CUTOFF - TYPE 4 MEDIUM - 6420 LUMENS | 5000K LED | 120-277 | 54 | LITHONIA | DSXW2LED-30C-530-50K-T4M-MVOLT | 1 |
| 10 | 10" SQUARE SURFACE LED CANOPY - 3500 LUMENS | 5000K LED | 120-277 | 27 | LITHONIA | CNYLED-P0-50K-MVOLT | 1 |
| l1 | 10" SQUARE SURFACE LED CANOPY - 4500 LUMENS | 5000K LED | 120-278 | 35 | LITHONIA | CNYLED-P1-50K-MVOLT | 1 |
| 12 | 10" SQUARE SURFACE LED CANOPY - 6600 LUMENS | 5000K LED | 120-278 | 52 | LITHONIA | CNYLED-P2-50K-MVOLT | 1 |
| K1 | 6" LED RECESSED DOWNLIGHT - 1000 LUMENS | 5000K LED | 120-277 | 10.4 | LITHONIA | LDN6-50/10-LO6-AR-LSS-MVOLT | 1 |
| Y1 | LED AREA FIXTURE - TYPE 2 MEDIUM - 14,716 LUMENS | 5000K LED | 120-277 | 125 | LITHONIA | DSX1LED-P4-50K-T2M-MVOLT-SPA | 1 |
| Y2 | LED AREA FIXTURE - TYPE 4 MEDIUM - 14,362 LUMENS | 5000K LED | 120-277 | 125 | LITHONIA | DSX1LED-P4-50K-T4M-MVOLT-SPA | 1 |
| Y2W | LED AREA FIXTURE - TYPE 4 MEDIUM - 14,362 LUMENS - WALL MOUNTED | 5000K LED | 120-277 | 125 | LITHONIA | DSX1LED-P4-50K-T4M-MVOLT-WBA | 1 |
| Y4 | LED AREA FIXTURE - TYPE FORWARD THROW MEDIUM - 14,672 LUMENS - HOUSE SIDE SHIELD | 5000K LED | 120-277 | 125 | LITHONIA | DSX1LED-P4-50K-TFTM-MVOLT-SPA-HS | 1 |
| LP1 | 20'-0" STRAIGHT SQUARE STEEL 5" POLE - SINGLE | - | - | - | LITHONIA | SSS-20-5C-DM19AS-IC | 1 |
| LP2 | 20'-0" STRAIGHT SQUARE STEEL 5" POLE - 2 @ 180° | - | - | - | LITHONIA | SSS-20-5C-DM28AS-IC | 1 |

3. ALL INTERIOR LED FIXTURES TO HAVE A MINIMUM CRI OF 80+. ALL EXTERIOR LED FIXTURES TO HAVE A MINIMUM CRI OF 70+.

4. MOUNT FIXTURES AT HEIGHT INDICATED ON DRAWINGS UNLESS NOTED OTHERWISE.

1. ARCHITECT TO SELECT STANDARD COLOR AND FINISH.

LED AREA FIXTURE POLE HEIGHT 20'-0" CONCRETE BASE BASE HEIGHT 36" LP1 & LP2 FIXTURE BASE DETAIL SCALE: NTS

GENERAL NOTES: 1. SITE LIGHTING CALCULATED AT GRADE. <u>a</u>

Office Locations: Milwaukee 829 S. 1st Street Milwaukee, Wisconsin 53204 T: 414.226.0200

Sheboygan 1227A North 8th Street PO Box 955 Sheboygan, Wisconsin 53082 T: 920.459.4200

www.brayarch.com

ADDITION AND F
BUTLER MIDDLE
SCHOOL DISTRI
310 N. HINE AVE **REVISIONS:**

⚠ DATE DESCRIPTION

Project Number:

Issued For:

CITY SUBMITTAL

11/06/2019 Sheet Title: SITE PLAN -

Sheet Number:

© 2018 Bray Associates Architects, Inc.

PHOTOMETRIC