



## COMMUNITY DEVELOPMENT

201 DELAFIELD STREET  
WAUKESHA, WISCONSIN 53188-3633  
TELEPHONE 262/524-3750 FAX 262/524-3751

Jennifer Andrews, Director  
jmandrew@ci.waukesha.wi.us

# NOTICE OF DECISION OF THE CHIEF BUILDING INSPECTOR

December 16, 2019

**Please take notice that the permit requested by application for the purpose for:**

Constructing a rec room with ceiling height of less than the required 7 feet in the basement of the single-family home and non-compliant stairs to basement located at **:210 Washington Ave, Waukesha, WI**, is hereby denied because the application fails to comply with the code of the City of Waukesha:

**Section 16.01 (b). This section adopts the Uniform Dwelling code for all new and existing one and two family dwellings. The Uniform Dwelling code, Chapter SPS 321.06, Requires a ceiling height of 7 feet. The Uniform Dwelling Code, Chapter 321.04 requires stairs and elevated areas to conform to this section.**

An appeal from this decision may be taken to the Board of Building Appeals as provided in the Code of the City of Waukesha. The appeal must be filed in the office of Community Development-Planning Department within twenty (20) days of the date of this notice.

---

Kristin Stone - Chief Building Inspector/Board of Building Appeals Secretary

