Project Reviews City of Waukesha

Project Number: SPAR19-00059 Description: Baker's Quality

Applied: 12/20/2019 Approved: Site Address: 1814 DOLPHIN DR

Closed: Expired: City, State Zip Code: WAUKESHA, WI 53186

Status: UNDER REVIEW Applicant: Keller, Inc. (Germantown)

Parent Project: Owner: **Tom Miller**

Contractor: <NONE>

Details:

PC19-0146

LIST OF REVIEWS										
SENT DATE	RETURNED DATE	DUE DATE	ТҮРЕ	CONTACT	STATUS	REMARKS				
Review Group: ALL										
1/2/2020	1/15/2020	1/12/2020	Sanitary Sewer	Chris Langemak	REVIEW COMPLETE	See comments				
Notes: 1. Sewer lateral video. The existing building has a sanitary sewer lateral connecting the City's sewer main. Please provide a sewer lateral video to City for review and approval. Contact the City Engineering Department for the video format. If lateral maintenance is needed, then the lateral improvements may need to be included as part of this project. The lateral pipe and connection to the main may need to be lined or relayed to reduce infiltration into the City's sanitary sewer system or improve the structural integrity.										
1/2/2020		1/12/2020	Traffic	Michael Grulke						
Notes:										
Review Group: AUTO										
12/20/2019	1/9/2020	1/9/2020	Building Inspection	KRISTIN STONE						
Notes:										
12/20/2019		1/9/2020	Fire	Brian Charlesworth						
Notes:										
12/20/2019	1/13/2020	1/9/2020	General Engineering	DAVID BUECHL	ADDITIONAL INFO REQUIRED	see notes				
Notes:										

- 1. Check if correct fees were paid.
- 2. Include scanned application as attachment.
- 3. Additional required submittals, fees, financial guaranties needed prior to issuance of building permit include:
- a. Letter of credits
- b. Applicable sewer connection charges per Chapter 29.11(c) will be owed to the City for this project.



Project Reviews City of Waukesha

12/20/2019	1/9/2020	Parks	Unassigned	
Notes:				
12/20/2019	1/9/2020	Planning	CHARLIE GRIFFITH	
Notes:				
12/20/2019	1/9/2020	Planning Commission	Unassigned	
Notes:				
12/20/2019	1/9/2020	Water Utility	Chris Walters	
Notes:				

