

Project Reviews

City of Waukesha

Project Number: SPAR20-00009

Description: **Mindiola Park**

Applied: **2/28/2020**

Approved:

Site Address:

Closed:

Expired:

City, State Zip Code: ,

Status: **UNDER REVIEW**

Applicant: **Engineering Department**

Parent Project:

Owner: **<NONE>**

Contractor: **<NONE>**

Details:

PC20-0020

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: ALL						
3/4/2020	3/13/2020	3/13/2020	Erosion Control	VELVET WEIER	REVIEW COMPLETE	See comments
Notes:						
A City of Waukesha Erosion Control plan is required, as well as a WPDES general permit through the DNR. Contact Velvet Weier with any questions - vweier@waukesha-wi.gov						
3/4/2020	3/17/2020	3/13/2020	Sanitary Sewer	Chris Langemak	REVIEW COMPLETE	See comments
Notes:						
1. If the concession stand & restrooms are added in the future, a service would need to be extended to Hoover and West Ave. The sanitary sewer in Hoover would need to be reconstructed due to sags in the line. Consider installing a grinder pump which would allow for the directional drilling of the force main in the landfill area which could also be sleeved through unused sewer in Hoover to avoid issues with the sags.						
3/4/2020	3/17/2020	3/13/2020	Storm Sewer	Chris Langemak	REVIEW COMPLETE	See comments
Notes:						
1. There is a reoccurring sink hole near Hoover Ave and the path. This should be investigated and repaired as necessary.						
3/4/2020	3/18/2020	3/13/2020	Stormwater	DAVID BUECHL	ADDITIONAL INFO REQUIRED	see notes
Notes:						
1. Label design elevations of drain tile pipe.						
3/4/2020	3/6/2020	3/13/2020	Street Lighting	JEFF HERNKE	REVIEW COMPLETE	See notes
Notes:						
No comments regarding City owned street lights or fiber.						

Project Reviews

City of Waukesha

3/4/2020	3/16/2020	3/13/2020	Traffic	Michael Grulke	REVIEW COMPLETE	No Comments
Notes:						
Review Group: AUTO						
2/28/2020		3/13/2020	Building Inspection	KRISTIN STONE		
Notes:						
2/28/2020		3/13/2020	Fire	Brian Charlesworth		
Notes:						
2/28/2020	3/18/2020	3/13/2020	General Engineering	DAVID BUECHL	REVIEW COMPLETE	see notes
Notes:						
1. No comments.						
2/28/2020		3/13/2020	Parks	Unassigned		
Notes:						
2/28/2020		3/13/2020	Planning	ROBIN GRAMS		
Notes:						
2/28/2020		3/13/2020	Planning Commission	Unassigned		
Notes:						
2/28/2020	3/17/2020	3/13/2020	Water Utility	Chris Walters	UNDER REVIEW	See comments
Notes:						
1) There is an existing water service stubbed out at the north property line. 2) A water service application must be submitted to tkrause@waukesha-water.com 3) Please provide a utility plan showing the proposed water main service. 4) Due to this being a possible contaminated soils area, nitrile gaskets must be used for all water main pipe and fittings.						