



COMMUNITY DEVELOPMENT

201 DELAFIELD STREET
WAUKESHA, WISCONSIN 53188-3633
TELEPHONE 262/524-3750 FAX 262/524-3751

Jennifer Andrews, Director

jmandrew@ci.waukesha.wi.us

NOTICE OF DECISION OF THE CHIEF BUILDING INSPECTOR

December 1, 2020

Please take notice that the permit requested by application for the purpose for:

Constructing habitable rooms in the basement with ceiling height of the stair less than the required 6'4" feet in a single-family home located at: **718 Greenmeadow Dr, Waukesha, WI**, is hereby denied because the application fails to comply with the code of the City of Waukesha:

Section 16.01 (b). This section adopts the Uniform Dwelling code for all new and existing one and two family dwellings. The Uniform Dwelling code, Chapter SPS 321.04(2)(d), Requires a ceiling in a stair to be a height of 6'4" feet.

An appeal from this decision may be taken to the Board of Building Appeals as provided in the Code of the City of Waukesha. The appeal must be filed in the office of Community Development-Planning Department within twenty (20) days of the date of this notice.

Kristin Stone - Chief Building Inspector/Board of Building Appeals Secretary

