



Waukesha Water Utility

SERVING WAUKESHA SINCE 1886

115 DELAFIELD STREET
WAUKESHA, WI 53188-3615

Telephone: (262) 521-5272 • Fax: (262) 521-5265 • E-mail: contactus@waukesha-water.com

MEMORANDUM

Date: December 9, 2020

To: Dan Duchniak, P.E.

From: Chris Walter, P.E.

Re: Area 1 & 2 Flood Mitigation and Resurfacing Change Order

As part of the City's 2020 Resurfacing Work, there were various locations where our existing water main was potentially in conflict with new storm sewer improvements part of the paving work. Although three (3) conflicts were anticipated, a total of five (5) conflicts were encountered during construction. The additional conflicts were due to field adjustments made to the new storm sewer culverts that placed them deeper than anticipated, which resulted in the need to lower or offset water main in two additional locations. The water main offsets were bid per each at a cost of \$8,500. As you may recall, all water main relocations resulting from City roadway and storms sewer improvements are the responsibility of WWU.

Therefore, I am recommending approval of a change order to the Area 1 & 2 Flood Mitigation and Resurfacing project in the amount of \$17,000.00.

Due to favorable bid costs and other capital projects being completed under bid costs, there are sufficient funds in the 2020 Transmission and Distribution budget.

Recommended Motion: Move to approve the change order with Wolf Paving in the amount of \$17,000.00 for the Area 1 & 2 Flood Mitigation and Resurfacing Project.

