Project Reviews City of Waukesha

Project Number: SPAR21-00012 Description: Proven Power Sports

Applied: 3/23/2021 Approved: Site Address: 1505 STH 164

Closed: Expired: City, State Zip Code: WAUKESHA, WI 53186

Status: UNDER REVIEW Applicant: Proven Power, Inc.

Parent Project: Owner: WAUKESHA 164 LTD PRTSHP

Contractor: <NONE>

LIST OF REVIEWS

Details:

PC21-0024

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS				
Review Group: ALL										
4/9/2021	4/14/2021	4/11/2021	Sanitary Sewer	Chris Langemak	REVIEW COMPLETE	See comments				
Notes: 1. Sewer lateral video. The existing building has a sanitary sewer lateral connecting the City's sewer main. Please provide a sewer lateral video to City for review and approval. Contact the City Engineering Department for the video format. If lateral maintenance is needed, then the lateral improvements may need to be included as part of this project. The lateral pipe and connection to the main may need to be lined or relayed to reduce infiltration into the City's sanitary sewer system or improve the structural integrity.										
4/9/2021	4/14/2021	4/11/2021	Storm Sewer	Chris Langemak	REVIEW COMPLETE	No comments				
Notes:										
4/9/2021	4/12/2021	4/11/2021	Street Lighting	Jeff Hernke	REVIEW COMPLETE	See notes				
Notes: No comments rega	rding City owned str	eet lights or fiber.								
4/9/2021	4/14/2021	4/11/2021	Traffic	Michael Grulke	REVIEW COMPLETE	No Comments				
Notes:										
Review Group: AUT	ТО									
3/23/2021	4/9/2021	4/6/2021	General Engineering	DAVID BUECHL	ADDITIONAL INFO REQUIRED	see notes				
Notes:	16									

- 1. No site plan submitted for review since disturbance is less than 3,000 sf.
- 2. Provide letter of credits required by Plan Commission for landscaping.
- 3. This is a location in the City where public sidewalk is recommended to be installed by City Staff along frontage of STH 164.



Project Reviews City of Waukesha

3/23/2021		4/6/2021	Planning	CHARLIE GRIFFITH							
Notes:											
3/23/2021	4/16/2021	4/6/2021	Water Utility	Chris Walters	APPROVED	No comments					
Notes:											

