

Project Reviews

City of Waukesha

Project Number: SPAR21-00013

Description: **HAC Overflow Shelter**

Applied: **4/13/2021**

Approved:

Site Address: **1210 SENTRY DR**

Closed:

Expired:

City, State Zip Code: **WAUKESHA, WI 53186**

Status: **UNDER REVIEW**

Applicant: **HOUSING ACTION COALITION OF**

Parent Project:

Owner: **HOUSING ACTION COALITION OF**

Contractor: **<NONE>**

Details:

PC21-0027

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: AUTO						
4/13/2021	4/13/2021	4/27/2021	Fire	Brian Charlesworth	REVIEW COMPLETE	See Notes
Notes: An automatic sprinkler system will be required in accordance with IFC Chapter 9.						
4/13/2021		4/27/2021	General Engineering	David Buechl		
Notes:						
4/13/2021		4/27/2021	Planning	CHARLIE GRIFFITH		
Notes:						
4/13/2021	4/16/2021	4/27/2021	Water Utility	Chris Walters	APPROVED	No comments
Notes:						