



## Legislation Details

<b>File #:</b>	ID#22-3370	<b>Version:</b>	1	<b>Name:</b>	
<b>Type:</b>	Business item	<b>Status:</b>		Agenda Ready	
<b>File created:</b>	1/3/2022	<b>In control:</b>		Board of Building Appeals	
<b>On agenda:</b>	2/15/2022	<b>Final action:</b>			
<b>Title:</b>	<p>The appeal of Jerimiah Mijokovich, owner of 935 N. Greenfield Ave, to appeal the cited violations of the Uniform Dwelling Code, sections, SPS321.06(3) as referenced by section 1601(b) of the Waukesha Building Code. The existing home was built in 1929, therefore, the owner is permitted to appeal the requirements as allowed in Code Section 16.17 of the Waukesha Building Code. The appellant alleges the provisions of the code do not cover ceiling height extending beyond the back from the water closet to slope to below 5 feet until beyond the back of the water closet. If the appeal is granted, the appeal would allow the ceiling height back from beyond the back of the water closet to be less than the required 5 feet and would allow a ceiling height beyond the back of the water closet to be 4 feet 10 1/2 inches. This would vary from the requirements of the Uniform Dwelling Code.</p> <p>SPS321.06 Ceiling height. All habitable rooms, kitchens, hallways, bathrooms and corridors shall have a ceiling height of at least 7 feet, except as follows: (3) The ceiling height extending back from the front edge of a water closet may slope to below 7 feet, but may not go below 5 feet until beyond the back of the water closet.</p>				

### Sponsors:

### Indexes:

### Code sections:

**Attachments:** 1. 935 N Greenfield Ave BBA Application, 2. 935 N Greenfield Ave, BBA appeal and code reference, 2-10-22, 3. 935 N Greenfield Ave BBA denial letter 2-10-22, 4. 935 Greenfield photos

Date	Ver.	Action By	Action	Result
2/15/2022	1	Board of Building Appeals	denied	Pass