

Project Reviews

City of Waukesha

Project Number: SPAR26-00014

Description: **Final SPAR - 2525 Aviation Dr**

Applied: **3/4/2026**

Approved:

Site Address: **544 NORTHVIEW RD**

Closed:

Expired:

City, State Zip Code: **WAUKESHA, WI 53188**

Status: **RECEIVED**

Applicant: **WALTERS BUILDINGS**

Parent Project:

Owner: **John Fischer**

Contractor: **<NONE>**

Details:

PC26-0027

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: AUTO						
3/4/2026	3/4/2026	3/18/2026	Building Inspection	KRISTIN STONE	REVIEW COMPLETE	No remarks
Notes:						
3/4/2026	3/4/2026	3/18/2026	Fire	Brian Charlesworth	REVIEW COMPLETE	None
Notes:						
3/4/2026		3/18/2026	General Engineering	Josh Meyerhofer		
Notes:						
3/4/2026		3/18/2026	Parks	Melissa Lipska		
Notes:						
3/4/2026		3/18/2026	Planning	Unassigned		
Notes:						
3/4/2026		3/18/2026	Planning Commission	Unassigned		
Notes:						

Project Reviews

City of Waukesha

3/4/2026	3/9/2026	3/18/2026	Water Utility	Mat Kadrich	REVIEW COMPLETE	see notes
----------	----------	-----------	---------------	-------------	-----------------	-----------

Notes:
Are 6" services needed? WWU will require water lateral applications for each building, forms can be found on our website with associated fees. WWU will provide the tapping sleeve, valve, valve box, and make the tap. The contractor is responsible for excavation, trench shoring, and means to lower parts into the ditch