

# Project Reviews

## City of Waukesha

**Project Number: SPAR25-00029**

**Description: 1610 E Main St, Woodman's Car Wash**

Applied: **6/25/2025**

Approved:

Site Address: **0 E MAIN ST**

Closed:

Expired:

City, State Zip Code: **WAUKESHA, WI 53186**

Status: **RECEIVED**

Applicant: **Fox Arneson, Inc.**

Parent Project:

Owner: **Woodman's Food Markets**

Contractor: **<NONE>**

Details:

**PC25-0121**

### LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: AUTO						
6/25/2025	7/2/2025	7/10/2025	Building Inspection	KRISTIN STONE	REVIEW COMPLETE	no remarks
Notes:						
6/25/2025	6/26/2025	7/10/2025	Fire	Brian Charlesworth	REVIEW COMPLETE	None
Notes:						
6/25/2025	7/11/2025	7/10/2025	General Engineering	Josh Meyerhofer	REVIEW COMPLETE	See notes
Notes:						
MSA review letter included in attachments						
6/25/2025		7/10/2025	Parks	Melissa Lipska		
Notes:						
6/25/2025		7/10/2025	Planning	Unassigned		
Notes:						
6/25/2025		7/10/2025	Planning Commission	Unassigned		
Notes:						

# Project Reviews

## City of Waukesha

6/25/2025	7/1/2025	7/10/2025	Water Utility	Mat Kadrich	REVIEW COMPLETE	see notes
-----------	----------	-----------	---------------	-------------	--------------------	-----------

Notes:

- 1) A water lateral application is required for meter sizing. All fees must be paid prior to starting installation. The forms can be found on our website.
- 2) If using PVC pipe it must be DR-14, and class 52 for DI pipe.