

WAUKESHA WATER UTILITY
Accident Damage Incident Report (Front)

TO BE FILLED OUT BY EMPLOYEE	
Name: <u>Mat Kaban</u>	Date of Report: <u>7-23-26</u>
Title: <u>Construction Manager</u>	
When Did Incident Occur: Date: <u>7-20-26</u>	Time: <u>3:15 pm</u>
Describe incident (be specific): <u>The sewer at 611 Ivy backed up, we replaced a hydrant near the address on 7/19/26. Did not notice anything at that time. The sewer was mismarked by approximately 6'</u>	
Where did the incident happen: (Give exact location such as customer address, street intersection, etc.) <u>611 Ivy cor.</u>	
How did the incident happen: <u>Apparently dug through mismarked sewer and did not notice any damage at the time. The owner at 611 Ivy called on 7/20/26 and stated a plumber uncovered the lateral and it was broken in a</u>	
Were there any witness(s) to the incident: ☐ Yes ☒ No <u>broken in a ditch</u>	
Name(s):	
What other factors were involved that may have contributed to the incident: <u>locates were off by 6'</u>	
What can be done to prevent similar incidents: <u>N/A</u>	
Additional Comments: <u>city crews made repair. We assisted them in making the repair</u>	
Employee Signature: <u>[Signature]</u>	Date: <u>7-23-26</u>

