

Project Reviews

City of Waukesha

Project Number: SPAR26-00042

Description: **Minor Site Plan - 1343 Ellis St , ZMG Addition**

Applied: **6/29/2026**

Approved:

Site Address: **1343 ELLIS ST**

Closed:

Expired:

City, State Zip Code: **WAUKESHA, WI 53186**

Status: **RECEIVED**

Applicant: **StrucRite, Inc.**

Parent Project:

Owner: **ZEHNDER MANAGEMENT GROUP LLC**

Contractor: **<NONE>**

Details:

PC26-0076

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: AUTO						
6/29/2026	6/30/2026	7/13/2026	Building Inspection	KRISTIN STONE	REVIEW COMPLETE	No remarks
Notes:						
6/29/2026	7/13/2026	7/13/2026	Fire	Brian Charlesworth	REVIEW COMPLETE	None
Notes:						
6/29/2026	7/13/2026	7/13/2026	General Engineering	Josh Meyerhofer	REVIEW COMPLETE	See notes
Notes:						
MSA comments included in attachments						
6/29/2026	7/15/2026	7/13/2026	Planning	Thane Brehmer	REVIEW COMPLETE	
Notes:						
6/29/2026		7/13/2026	Planning Commission	Unassigned		
Notes:						
6/29/2026	7/1/2026	7/13/2026	Water Utility	Mat Kadrach	REVIEW COMPLETE	see notes
Notes:						
There is currently a 1" copper water service to the building. If a larger service is needed for fire protection WWU will need a water lateral application, and the work will need to be inspected by us.						